

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO. F6/DFS/MS/EH/NDZ/2018/

13)

Dated:

22/01/18

FIRE SAFETY CERTIFICATE

Certified that the M/S Chaupal Restaurant is running at ground plus one upper floor of the building which is comprised of ground plus two upper floors at F-3/11-12, Main Road (Parts), Krishna Nagar, Delhi-51 was granted Fire Safety Certificate vide letter No. F6/DFS/MS/EH/2015/NDZ/626 dated 27.04.2015. The restaurant was re-inspected by the officer concerned of this department on 08/01/18 in the presence of Mr. Anil Kapoor and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the restaurant is fit for occupancy class "Eating House (Restaurant)" with effect from ...22/01/18... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on.....22/01/18.....at New Delhi by

22/01/18
(Vipin Kental)
Chief Fire Officer

o/c/r/s

To,

M/S Chaupal Restaurant
F-3/11-12, Main Road (Parts), Krishna Nagar, Delhi-51

Copy to:-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone,
Karkardooma, Delhi

Conditions -

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
- 6 This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Chaupal Restaurant, F3/11-12 Main Road Parts, Krishna Nagar, Delhi-51.
2. Building is comprised of : Restaurant is running at ground plus one upper floor of the building which is comprised of ground plus two upper floors
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/EH/2015/NDZ/626 dated 27.04.2015
6. Fire Safety direction letter No : Old requirements
7. Date of Inspection : 08/01/18
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer from the building side : Mr. Anil Kapoor
10. Year of Construction : 2005
11. Applicant's letter No : Nil dated 29/11/17

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old restaurant requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	N/A	N/A	N/A
	B. Width of Staircases			
	Upper Floor	1.2 m	1.2 m, 1.0 m	MR
	Basement	N/A	N/A	N/A
	c. Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door size	1.5 m	1.5 m, 1.1 m	MR
i. no. of doors	2 no.	2 no.	MR	
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A

5.	Fire Extinguisher			
	• Total numbers	04 no.	08 no.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of main panel	N/A	N/A	N/A
	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooters's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	1 no.	1 no.	MR
	Hose Box	1 no.	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	5000 Liters	5000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/EH/2015/NDZ/626 dated 27.04.2015 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

R. K. Yadav

Signature of the Inspecting Officer 10/1/2018
 Name : R. K. Yadav
 Designation ADO (LN)

submitted for approval plan

DO (EAST)

DU/FO/NDZ.
[Signature]

[Signature]
 11/1/18.

352/cfo/NDZ
16/1/22-1

C.F.P. M.Scell FTW.
16/1

Sy FT letter to put up for signature pl