

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2018/ w2/140

Dated: 23/01 /2018

FIRE SAFETY CERTIFICATE

Certified that the **Aggarwal City Mall**, Located at **Plot No – 05, Road No-44, Pitampura, Delhi – 110034**, comprised of Basement + Ground + 3 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2014/WZ/58 dated 15-01-2014. The premises was re inspected by the team of officer of this department on 04-01-2018 in the presence of **Mr. Sunil Jain** & found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Mercantile Building" Group F with effect from 23/01/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/01/18 at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

Sh. Sunil Jain
Aggarwal City Mall, Plot No – 05, Road No-44, Pitampura, Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the doors, Exits and internal roads must be kept free from any obstruction.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry

INSPECTION REPORT

1. Name & address of the building: **Aggarwal City Mall, Located at Plot No – 05, Road No-44, Pitampura, Delhi – 110034**
2. Type of Occupancy : Mercantile(B + G + Three Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2014/WZ/58 dated 15-01-2014
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/2005/1527 dated 19-07-2005
6. Date of inspection : 04-01-2018
7. Name of the Inspecting Officer : DO/W & ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Sunil Jain
9. Year of Construction : 2005-2006
10. Applicant's letter No. : NDPPL/DIR/AMP5/DFS/2K17/0589 Dated-11/12/17

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	24 m	24mtr Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	As per sanction plan	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2+1 Ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m	1.5m & 1.6m	MR
	• Basements	1.5m	Varies from 1.35 to 1.85m & 1to 0.8m & 1.8m	MR(Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Not Required	Not Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5m	Hall (Old case)	MR
	f. Door Size	1.m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 a/c per hrs	Functional	MR
	• Upper floors	12 a/c per hour	Provided(Not)	MR

6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	2	2 Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	MR
		Ground Floor	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power Hooters' Location 	Required	Provided	MR
		At Strategic Location	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	2	2 Provided	MR
	<ul style="list-style-type: none"> Hose Box 	2 Required	2 Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required	4 Provided	MR
		Required	4 Provided	MR
13.	Pumping Arrangements Common with adjoining building at ground level			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump 	2280 lpm	2280 lpm	MR
	<ul style="list-style-type: none"> ➤ Head of main pump 	60 m	60 m	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	01	01	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	180 lpm	180 lpm	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	60 m	60 m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	2280 lpm	2280 lpm	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	60 m	60 m	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Power supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto starting of pump 	NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	2,00,000 litres	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw of connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> • Overhead Tank capacity 	20, 000 litres	Provided	MR
15.	Exit Signag	Required	Provided	MR

16.	Provision of Lifts (Lift Run from Ground to 3 rd Floor)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Manually operated CO2 system	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/2014/WZ/58 dated 15-01-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

[Handwritten Signature]
5/1/18

Signature of the Inspecting Officer

[Handwritten Signature]
5/1/18

Name Uday Vir Singh
Designation ADO/wp

Name Sh. Mukesh Verma
Designation DO/w

[Handwritten Note]
By (WZ) speak reg internal road mentioned at N/37

[Handwritten Signature]
DO/w

[Handwritten Signature]
8/1/18

[Handwritten Note]
spoken the building is low rise.

[Handwritten Signature]
DO/w

[Handwritten Signature]
18/1/18

[Handwritten Signature]
18/1/18