

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/2018/183

Dated: 30/01/2018

FIRE SAFETY CERTIFICATE

Certified that the **M/s Suravie Restaurant (Unit of Royal Hospitality)** Located at **101, FF Plot no. C-4,C-5,C-6, Aggarwal Cyber Plaza Tower -1, Netaji Subhash Palace, Pitampura, Delhi** was issued FSC vide Letter No. F6/DFS/MS/EH/2014/WZ/1378 dated 10/11/2014. The premises was re inspected by the officers of this department on 20-12-2017 in the presence of Mr. Sachin (Manager) found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 30.01.2018 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30.01.2018 at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Deputy Health Officer West Zone, Vishal Enclave, New Delhi
2. The (Manager) **M/s Suravie Restaurant (Unit of Royal Hospitality)** Located at **101, FF Plot no. C-4,C-5,C-6, Aggarwal Cyber Plaza Tower -1, Netaji Subhash Palace, Pitampura, Delhi**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: **M/s Suravie Restaurant (Unit of Royal Hospitality) 101, FF Plot no. C-4,C-5,C-6, Aggarwal Cyber Plaza Tower -1, Netaji Subhash Palace, Pitampura, Delhi**

2. Type of Occupancy : Assembly

3. Type of Case : Renewal

4. Details of previous NOC : F6/DFS/MS/2014/EH/WZ/1378 dated 10-11-2014

5. Fire Safety directives Letter No. : FSC Issued to the building

6. Date of inspection : 20-12-2017

7. Name of the Inspecting Officer : DO/W & ADO (WP)

8. Name and designation of Officer

from the building side : Mr. Sachin

9. Year of Construction : 2007,08

10. Applicant's letter No. : nil dated -27.11.2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	22.4m Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 m	225cm & 229cm	MR
	• Basements	NR for Restaurant	NR for Restaurant	NR for Restaurant
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	175 cm & 140cm (Old Case)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust Fans	MR
	• Upper floors	12 a/c per hour	Provided	MR

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 nos. DCP, CO2 & WCO2 ISI marked	8 Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required Required Required	Provided Provided Provided	MR MR MR
11.	Internal Hydrants: common with the mall			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm 01 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements: (Common with the mall)			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA NA NA NA NA NA NA NA Required 450 lpm 40 m Required Required	2850 LPM 100 m 02 180 100m NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA MR MR MR MR MR

14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	100000 litres	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided 50000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage			
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Co2 Flooding for DG HT & LT Pannel	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. : **F6/DMS/MS/2014/WZ/325, Dated- 10-03-2014** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Sh Mohesh Verma

Designation

ADD/WP

Designation

DO/W

Dy. CPO (WZ)
CPO-west/1.118

28/1/18