

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / *schwd/wz/176*

Dated: *28* / *11* / 2018

FIRE SAFETY CERTIFICATE

Certified that the **Shreesainath Education Society** located at **Kh.no.215, 214/1, 212, Mungesh Pur, Delhi-110039** comprised of Ground and one upper floors owned/ occupied by **Shreesainath Education Society** was granted NOC by this department vide letter No **F6/DFS/MS/2014/WZ/711** dated **11.06.2014**. The premises have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 18.01.2018 in the presence of **Sh. Yogender Kumar , Chairman** and that the building/premises is fit for occupancy Group B Educational for ground and first floor only with effect from ..*28.11.18*..... for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on ..*28.11.18*..... at New Delhi

Atul Garg
(Atul Garg)
Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Chairman, Shreesainath Education Society, Kh.no.215, 214/1, 212, Mungesh Pur, Delhi-39.

INSPECTION REPORT

1. Name & address of the building : Shreesainath Education Society, Kh.no.215, 214/1, 212, Mungesh Pur, Delhi-110039.
2. Type of Occupancy : Educational (G+01 Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2014/WZ/711 dated 11.06.2014.
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 18/01/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mr. Yogender Kumar (Chairman)
9. Year of Construction : 2013
10. Applicant's letter No. : Nil Dated- 25/11/2017

Plot Area- 2533.24 m²

Covered Area: 1570.54 m²

class rooms -08 nos

students - 156nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	3m (old case)	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR(old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.53m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	1 m & Hall	1m & Hall - 1.75m each(2 exits)	MR

1

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	13nos	13nos	MR
	• Types	ABC/CO2	ABC—13	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
	NA	NA	NA	NA
9	Public Address System.			
	NA	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
12	Yard Hydrants.				
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA	
		NA	NA	NA	
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
		14	Captive Water Storage for fire fighting.		
<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			NA	NA	NA
	NA		NA	NA	
	NA		NA	NA	
	NA		NA	NA	
	NA		NA	NA	
NA	NA	NA			
15	Exit Signage.	NA	NA	NA	
16	Provision of Lifts.				

Handwritten signature

Handwritten mark

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 17.01.2005 the FSC issued vide letter of even no 711 dated 11.06.2014 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN


 28/1/18
 Dy. CSE
 C/o. West
 23/1/18
 FT PLS

ADO/RN As approved, F.T. letter in put up for
 your signature pl
 C/o. West
 25/1/18
 (All 25/1)