

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/School/2018/WZ/ 178

Dated: 28 /01/2018

FIRE SAFETY CERTIFICATE

Certified that the **Kailash Memorial Charitable Society**, Located at **Plot no 12, FC-57, Road no 44, Pitam Pura, Delhi** comprised of Basement + Stilt + Ground + 02 Upper Floors was issued FSC vide Letter No. F-6/DFS/MS/School/2014/WZ/1369 Dated 05-11-2014. The premises was re inspected by the officer concerned of this department on 01-01-2018 in the presence of Mr. Sandeep Kumar (Employee) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance NBC part- IV and that the premises is fit for occupancy class "Educational" Group B with effect from 28/1/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28.1.18..... at New Delhi by.

(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

The Principal, Kailash Memorial Charitable Society, D-6/6, Rana Pratap Bagh, Delhi 110007.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. All the exit route shall be kept free from any obstruction.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Kailash Memorial Charitable Society,
Located at Plot no 12,FC-57, Road no 44, Pitam Pura, Delhi

D-6/6, Rana Pratap Bagh, Delhi 110007

2. Type of Occupancy : Educational (Basement + Stilt + Ground + 2
Upper Floor)

3. Type of Case : Renewal

4. Details of previous NOC : F-6/DFS/MS/School/2014/WZ/1369 Dated
05-11-2014

5. Fire Safety directives Letter No: Cr.No.3298-3398 dated 1-3-11

6. Date of inspection : 01-01-2018

7. Name of the Inspecting Officer : DO/W & ADO (WP)

8. Name and designation of Officer

from the building side : Mr. Sandeep Kumar (Principal)

9. Year of Construction :

10. Applicant's letter No. : Nil Dated Nil

No. of Students=36
No. of class rooms=18
Plot area= 861sqm
Covered area=860sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11/NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	12 m Provided	MR
	• Gate width	Accessible	380cm Provided(Old Case)	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m	1x145,1x150cm	MR
	• Basements	1.5 m	1x150cm,1x135cm	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1mtr	111cm	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR

5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box			
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	50MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	15,000Ltr	Provided	MR
	• Overhead Tank capacity			

16.	Provision of Lifts(Lift will Run from G toUF)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F-6/DFS/MS/School/2014/WZ/1369 Dated 05-11-2014 ren ewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Uday Vir Singh

Name Sh Mohesh Verma

Designation ADO/W P

Designation DO/W

Dy CPO (WZ)
CPO West
PH/18
 IS this building covered under
 DFS Act & Rule 20/0 ?
19/11/18