

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2018/ 186

Dated: 30/01/18

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School No.-1 (ID-1515026) located at Tagore Garden, New Delhi-110027, comprised of Ground Floor & Ground + one upper floor only owned / occupied by Govt. Girls Sr. Sec. School No.-1, has already been issued NOC / FSC by this department vide letter No. F6/DFS/MS/School/2014/WZ/1138 dated 05/09/2014. The premises was re-inspected by the officer concerned of this department on 11.01.2018 in the presence of Sh. Dev Raj (Estate Manger) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class Educational (Group B) with effect from ...30/01/18.....for a period of 3 (three) years subject to conditions printed below.

Issued on 30/01/18 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Vice Principal, Govt. Girls Sr. Sec. School No.-1 (ID-1515026), Tagore Garden, New Delhi-110027.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
7. Auditorium shall not be used for any purpose as it does not have required Fire Safety Measures and declared dangerous by P.W.D.

INSPECTION REPORT

1. Name & address of the building: **Govt. Girls Sr. Sec. School No.-1 (ID-1515026), Tagore Garden, New Delhi-110027.**
2. Type of Occupancy : **Educational (G+1)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/School/2014/WZ/1138 dated 05/09/2014**
5. Fire Safety directives Letter No. : **DOE Circular dated 01.03.2011**
6. Date of inspection : **11/01/2018**
7. Name of the Inspecting Officer : **A. K. Jaiswal**
8. Name and designation of Officer
from the building side : **Sh. Dev Raj (Estate Manager)**
9. Year of Construction : **1968**
10. Applicant's letter No. : **GGSSS/TG/2017-18/755 dated 29/11/2017**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dated 1/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr x 2	1.50 mtr x 2	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.00 mtr.	1.00 mtr (Double Door)	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	25	29	MR
	• Types	ISI marked ABC/CO ₂	Provided	M/R

6.	First - Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater	N/A	N/A	N/A
	• Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A

2/10

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/School/2014/WZ/1138 dated 05/09/2014** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O. / (rest)

What about auditorium?

Inspected 16/1/18

Ashok Kumar Jaiswal
12/1/2018

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

ADO (JWP)

Audi is not being used as it is abandoned by school authorities in that PWD being in