

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/SZ/2018/

196

Dated:

31/01/18

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Celebi Delhi Cargo Terminal Management India Pvt. Ltd. (Export & Import House), IGI Airport, New Delhi-110037** comprised of ground and one upper floor has already been issues FSC by this department vide letter no. F6/DFS/MS/2015/799 dated 19/05/2015. The premise was re-inspected by the officer concerned of this department on 18/01/2018 in the presence of Mr. Rakesh (Fire Officer) and found that the said building blocks have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that these building blocks is deemed fit for occupancy class "**Group-H (Storage Building)**" with effect from ~~31/01/2018~~ 31/01/2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....31/01/18.....at New Delhi by.

31/1  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to:-

1. Sh. Ramesh Mamidala (CEO), M/s Celebi Delhi Cargo Terminal Management India Pvt. Ltd., IGI Airport, New Delhi-110037.
2. Sh. Hrishekan, GM (Fire), New Udaan Bhawan, Terminal-3, IGI Airport, New Delhi-110037

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."



: Group-H (Storage Building)

: Renewal

: F6/DFS/MS/2015/799 dated 19/05/2015

: F6/DFS/MS/BP/380 dated 20/02/1998

: 18/01/2018

: A. K. Malik

: Mr. Rakesh (Fire Officer)

: 1988

: Form "J" outdoor diary no. 391 dated 09/01/2018

2. Type of Occupancy
3. Type of Case
4. Details of Previous NOC
5. Fire Safety directives letter No
6. Date of inspection
7. Name of Inspecting Officer
8. Name and designation of officer from the building side
9. Year of Construction
10. Applicant's letter No.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directive/BBL/NB C Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	9m 5m 6m	Provided Provided Provided	MR MR MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	5 Nos NA	14 Nos (8 Nos on city side & 6 Nos on Air side) NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.25m NA	(3 x 1.5m, 2 x 1.7m, 1.3m, 1.4m, 1.12m & 5 x 1.3m, 1.25m) NA	MR (Old Case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA Provided	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.25m 1m	1.5m 1m	MR MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA Required NA NA NA	NA Provided NA NA NA	NA MR NA NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA 12 ACPH	NA E. Fan Provided	NA MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	300 Nos ABC/W.CO <sub>2</sub> /CO <sub>2</sub> /Foam ISI marked	Provided 150/80/60/10 Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	GF-54 Nos, FF-20 Nos 30m 6mm	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Smoke & Heat	Smoke, Heat & Beam	MR



	<ul style="list-style-type: none"> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Ground Floor Required Required Required	Provided FCC (T-3) Provided All Floors	MR MR MR MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA Required Required	NA Provided Provided	NA MR MR
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150mm GF-54 Nos, FF-20 Nos GF-54 Nos, FF-20 Nos	Provided Provided Provided	MR MR MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	16 Nos 16 Nos	Provided Provided	MR MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	4500 LPM 88m Two 2 x 450 LPM 88m 4500 LPM 88m Required Required NA NA NA NA	Provided Provided Provided Provided Provided Provided Provided Provided Provided NA NA NA NA	MR MR MR MR MR MR MR MR MR NA NA NA NA
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	9,00,000 Required Required Required NA	7,50,000 Liters Provided Provided Provided NA	MR (old case) MR MR MR NA
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	NA NA	NA NA	NA NA
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> </ul>	Required Required	Provided Provided	MR MR

	<ul style="list-style-type: none"> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	HVWSS for transformer & clean agent automatic flooding in HT & LT panels	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures as required under the rule 35 of the Delhi Fire Service Rules 2010, Fire Safety Certificate is recommended.

Accordingly DFA of Form "H" is put up for approval and signature.

*Anilash*  
22/1/18

Signature of Inspecting Officer  
Name: A. K. Malik  
Designation: DO (SD)

Dy. CFO (SZ)

1562/cfo/sz  
29/1/31/1

*Handwritten signature*  
24/1



*cfo (SZ)*

m-scell

FTB.

*Handwritten signature*  
29/1

*Handwritten note: F.T. is put up for S's please.*

*Handwritten signature*

m-scell *Handwritten signature*  
31/1

*Anilash*  
30/1/18  
DO (SD)