

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI


No. F6/Dfs/ms/2018/w2/203

Dated: 2/2/18

**FIRE SAFETY CERTIFICATE**

Certified that the **Community Facility in Residential and Flatted Factory Complex, Plot No. 15, Shivaji Marg, New Delhi – 110015** comprised of Ground plus 04 upper floors owned/occupied by **DLF Home Developers Limited** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 24-01-2018 in the presence of Mr. Siddhartha Malhotra (VP – Coordination) and found that the said building that the premises is fit for occupancy class “Assembly” Group D with effect from 2/2/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 2/2/18..... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
o/c @ 2/2/18

Copy to:

1. The Authorized Signatory,  
DLF Home Developers Ltd.  
DLF Centre, Sansad Marg, New Delhi – 110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**Complex, Plot No. 15, Shivaji Marg, New Delhi – 110015.**

2. Type of Occupancy : Assembly (comprised of Ground plus 04 upper floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2012/2651 dated 23/07/2012
6. Date of inspection : 24-01-2018
7. Name of the Inspecting Officer : DO (West) & Dy. CFO (WZ)
8. Name and designation of Officer  
from the building side : Sh. Siddhartha Malhotra (VP – Coordination)
9. Year of Construction : 2017
10. Applicant's letter No. : Nil Dated 21-11-2017 & 21-12-2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	12 m 4.5 m 6 m	12 m Provided On main road 6m Provided	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul> b. Width of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul> c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul> d. No of continuous staircase to terrace	03 NA  02 m NA  Required NR 03 2 m 2 m	03 Provided NA  02 m Provided NA  Provided NR 03 Provided Provided Provided	MR  MR MR MR MR MR MR MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required Required NR NR	Provided Provided Provided NR NR	MR MR MR NR NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA Natural Ventilation	NA Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	4 nos. per floor CO <sub>2</sub> & ABC ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	02 30 m 5 mm	02 Provided Provided Provided	MR MR MR



	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required	Provided	MR
		G.F.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		At strategic location	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm/100 mm	Provided	MR
		2	2 Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Required	Provided	MR
		Required	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>			
		2280 LPM	2850 lpm Provided	MR
		90 m	Provided	MR
		2	Provided	MR
		2X180 LPM	180 lpm Provided	MR
		160 m	Provided	MR
		1X2280 LPM	1X2850 lpm Provided	MR
		90 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NR	450lpm Provided	NR
		NR	35 m Provided	NR
		NR	Provided	NR
		NR	Provided	NR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	1 lac ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 ltrs	14,000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	Required	Provided	MR
		Pressurization/ Natural Ventilation in service lift	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	Fire control room:			
	<ul style="list-style-type: none"> <li>Detector system panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> </ul>	Required	Provided	NR
		Required	Provided	MR
		Required	Provided	MR

	➤ Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

*[Handwritten Signature]*  
1/2/18

Signature of the Inspecting Officer

Name: Dharampal Bhardwaj

Designation: Dy.CFO (West Zone)

*[Handwritten Signature]*  
29/1/18

Signature of the Inspecting Officer

Name: Mukesh Verma

Designation: DO (West)

*[Handwritten Signature]*  
cfo. west  
1/2/18

FT. Pls

*[Handwritten Signature]* F.T. is put up for signature please.

*[Handwritten Signature]*  
2/2/18

*[Handwritten Signature]*  
cfo (west zone)  
1/2/18