

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2017/NDZ/ 234

Dated: 9/2/18

FIRE SAFETY CERTIFICATE

Certified that the M/s St. Krishna Bodh Public School, 147,148,&149, Mandoli Road West Nathu Colony, Shahdara, Delhi-93, comprised of Ground plus three upper floors owned / occupied by St. Krishna Bodh Public School was issued FSC vide letter No. F6/DFS/MS/School/2014/NDZ/1321 dated 21/10/14. The school building was re-inspected by the officer concerned of this department on 29/01/18 in presence of Sh. Sharma (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with DFS Act 2007 and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from ..9.2.18.....for a period three year, subject to conditions printed overleaf.

Issued on.....9.2.18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

o/c of

To,  
St. Krishna Bodh Public School, 147,148,&149, Mandoli Road  
West Nathu Colony, Shadara, Delhi-93.

Copy to:-  
The Director of Education,  
East Delhi Municipal Corporation,  
419, Udyog Sadan, Patparganj Industrial Area, Delhi-110092.

**- Conditions -**

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : St. Krishna Bodh Public School, 147, Mandoli Road West Nathu Colony, Shadara, Delhi-93.
2. Building is comprised of : Ground + 3 upper floors,
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2014/NDZ/1321 Dated 21/10/14
6. Fire Safety circular No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 29/1/18
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer from the building side : Sh KD Shrama (Manager)
10. Year of Construction : 1998-1999
11. Applicant's letter No : NIL Dated - 15/01/18.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	07 Mtrs	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01.	01 no.	MR Old Excepted
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.5Mtrs	1.5 Mtrs	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	N/A.	N/A.	N/A.
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08 nos.	08 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

*h*



N/A

6	First-aid-Hose Reels.			
	Total numbers of each floor	01no	01no	M/R
	• Length of hose reel hose	30M	30M	M/R
	• Nozzle diameter	5 mm	5 mm	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	40M	40M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000Ltrs.	10,000Ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the DFS Act, 2007 and rules 2010.

The Fire safety Certificate issued vide letter no.F.6 / DFS / MS / School / 2014 / NDZ / 1321 dated 21/10/2014 has renew under rules is recommended to renewal under rule 37 of the Delhi Fire Service Rule 2010.

*Om Prakash*  
30/11/2018

Signature of the Inspecting Officer  
Name: Om Prakash  
Designation: ADO (Sahadara)

*Submitted for approval pm,*

DO (East)

*For copy*  
30/11/18

Dy.CFO /NDZ

*[Signature]*

*F.P.M.*

*CFP*

*M-scell*

*U 2/2*

*368/cfo #02*  
*6/2/9/2*

*F/T Letter is Put up for your signature please.*

*DO (E D)*