

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001




NO.F6/DFS/MS/School/2018/SZ/ 232

Dated: 9/2/18

FIRE SAFETY CERTIFICATE

Certified that the New Ring Midways Public School, located at E-109, Nanhey Park Uttam Nagar, New Delhi-110059, comprised of ground plus two upper floors was granted Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2013/SZ/1015 dated 3.10.2013. The said building was re-inspected by the officer concerned of this department on 24.1.2018 in presence of Sh. Satbir Solanki (owner) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular dated 1.3.2011, and that the building is fit for occupancy class B "Educational building" for ground plus three upper floors with effect from.....9/2/18.. for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on9/2/18..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service



Copy to:-

1. Director (Education), GNCT of Delhi, Old Secretariat, New Delhi.
2. Manager, New Ring Midways Public School, located at E-109, Nanhey Park Uttam Nagar, New Delhi-110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	New Ring Midways Public School at E-109, Nanhey Park, Uttam Nagar, New Delhi.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+2)		
4	Details of previous NOC	F6/DFS/MS/School/2013/SZ/1015 dated 3.10.2013		
5	Fire safety directives letter No	Directorate of Education:F-16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011		
6	Date of inspection	24.1.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Satbir Solanki (owner)		
9	Year of construction	before 2010		
10	Applicant's letter No.	MISC/NRMPS/AR/2017 dated 4.1.2018		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE CIR. 1.3.2011/ letter dated 3.10.2013	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.50 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 No.	2 No.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs. if less than 1.50 Mtrs. additional staircase of .75 Mtr. is required	1.25 Mtrs. each	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
		12 a/c charge		
	upper floors		Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	One No. CO2 OR ABC for every 300 Sq.Mtrs.	6 Nos.	MR
	Types	ISI Marked	ABC	MR
	ISI marking	ISI Marked	ISI Marked	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 Lpm.	Provided	MR
	b. head of the pump	35 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Lts.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/11

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher provided near electric meter.	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcomings vide letter dated 18.1.2017 found rectified.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE CIR. dated 1.3.2011, renewal of FSC issued vided letter no.F6/DFS/MS/School/2013/SZ/1015 dated 3.10.2013 is recommended.

Accordingly DFA is put up for approval and signature please.

Sem
29/1/18
S.P. Bhardwaj
ADO (Dwarka)

~~DO/20~~

Ug
29/1/2018

37/20/20
29/1/2018

DCFO (S2)



1576/cfo s2
212/9/2

leaf
30/1

CFO s2

Miscell

FTM.

Ug
2/2

FT is put up for signature please

cfo s2

Miscell

Ug
2/2

Sem
29/1/18