

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHTPLACE  
NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2018/ 236

Dated: 9/2/18

FIRE SAFETY CERTIFICATE

Certified that the Mayur Public School, I.P. Extension Delhi-92, owned/occupied by Mayur Public School, comprised of ground plus three upper floors was granted FSC vide letter no. No. F.6/DFS/MS/School/2014/NDZ/1473 dated 27/11/14. The school building was inspected by the officer concerned of this department on 18/01/18 in the presence of Smt.Shakuntla Rawat (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Act 2007 and Rules 2010 and found that the building is fit for occupancy class B "Educational Building" with effect from ....9/2/18..... for a period of **three years**, subject to conditions printed overleaf.

Issued on .....9/2/18..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

To,  
The Principal  
Mayur Public School,  
I. P. Extension Delhi - 92.

Copy to:-  
The Joint Director of Education  
(Land & Estate)  
Directorate of Education, Lucknow Road, Delhi-54.

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
1. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
2. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
3. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

- N/18
1. Name & address of the building : Mayur Public School, I.P. Extension Delhi-92
  2. Building is comprised of : G+3 upper floors
  3. Type of Occupancy : Educational
  4. Type of Case : Renewal
  5. Details of Previous FSC letter : F.6/DFS/MS/School/2014/NDZ/1473 Dated 27/11/14
  6. Fire Safety circular No : Delhi Fire Service Act, 2007 and Rules 2010
  7. Date of Inspection : 18/01/18
  8. Name of the Inspecting officers : ADO R K Yadav
  9. Name and designation of Officer  
from the building side : Smt.Shakuntla Rawat (Principal)
  10. Year of Construction : 2000
  11. Applicant's letter No : NIL dated 05/01/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 Mtrs	10 Mtrs	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	02 no.	02 no.	MR
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	1.5 m	1.7 m each	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 nos.	02 nos.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• types</li> </ul>	12Nos.	Provided	MR
		ABC & Co2	Provided	MR
	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>	ISI marked	Provided	MR



6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 mm	MR
	• Number of hydrants per floor	N/A	02 nos.	MR
	• Hose Box	N/A	02 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	provided	MR
	➤ Auto Starting of pump	Required	provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000Liters	10,000Liters	MR
15	Exit Signage.	Required	provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The building was issued shortcomings vide letter no. F6/DFS/MS/School/2017/2863 dated 07/12/2017 which is rectified. The same were checked and found functional at the time of inspection. ✓

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.


*R K Yadav*

Signature of the Inspecting Officer <sup>25/01/2018</sup>  
 Name : R K Yadav  
 Designation: ADO (LN)

*submitted for approval. please*

DO (East)


*367/CF/ND2  
2/2/19/2/18.*

*D4 (CF) ND2*  


*for of  
23/1/18.*

*L.F.P. miscell*  
*FTM.*  


*Say FT helter is put up for signature please*

*CFE (ND2) miscell*  


*R K Yadav*  
 8/2/2018