

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2017/NDZ/ 230

Dated: 9/2/18

FIRE SAFETY CERTIFICATE

Certified that the M/s K.D. Public School, W-33, Bhagat Singh Gali Babarpur, Shahdara, Delhi - 110032, comprised of Ground plus one upper floor owned / occupied by K.D. Public School was issued FSC vide letter No. F.6/DFS/MS/School/2014/NDZ/1257 Dated 07/10/14. The school building was re-inspected by the officer concerned of this department on 25/01/18 in presence of Subhash Gupta Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 9/2/18.....for a period three year, subject to conditions printed overleaf.

Issued on.....9/2/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

o/c of

To,
K.D. Public School,
W-33, Bhagat Singh Gali Babarpur,
Shahdara, Delhi - 110032.

Copy to:-
The Director of Education
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industiral Area, Delhi-92.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : K.D. Public School, W-33, Bhagat Singh Gali, Babarpur, Shahdara, Delhi - 110032.
2. Building is comprised of : G+ First Floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2014/NDZ/1257 Dated 07/10/14
6. Fire Safety direction letter No : Old requirement(Circular No. 262-362 dated 17/01/05)
7. Date of Inspection : 25/01/2018
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer from the building side : Subhash Gupta (Manager)
10. Year of Construction : 1975
11. Applicant's letter No : NIL Dated - 11/01/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 Mtrs N/A N/A	4.5 Mtrs N/A N/A	MR/old case N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	01 no. N/A	02 no. N/A	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	1.5 m N/A	0.75 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers types ISI marking 	04 nos. ABC & Co2 ISI marked	04 nos. ABC & Co2 ISI marked	MR MR MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 nos.	01 nos.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	220 LPM	220 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 Liters	2500 Liters	MR
15	Exit Signage.	N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules, it is recommended to renew Fire Safety Certificate.

Ombakash
30/11/2018

Signature of the Inspecting Officer
Name: Om Prakash
Designation: ADO (Shahdara)

DO (East) *Submitted for approval*

Om Prakash
30/11/18

Dy. CFO/NDZ

[Signature]

369/CFO/NDZ
24/9/2

C.F.O. *m.s. u* *2/2*