

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2018/SZ/ 231

Dated: 9/2/18

FIRE SAFETY CERTIFICATE

Certified that the building of Durga Public School located at RZ-28 & 31/184 Durga Park, Street No.2, New Delhi-110045, having two blocks Namely Block A & B Block, A Block is comprised of basement, ground plus one upper floor and Block B comprised of ground plus one upper floor, but school is running at ground floor in each block having total 08 rooms (Including class rooms & office) was issued Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/SZ/2014/286 dated 28.2.2014. The said school building was re-inspected by the officer concerned of this department on 24.1.2018 in presence of Sh. Vipin Panwar (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular no. F16/Estate/CC/Fire Safety/20113298-3398 dated 1.3.2011 and that the Premises/building is fit for occupancy of class B "Educational Building" (At ground floor only) with effect from9/2/18..... for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on9/2/18..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:

- 1 Director (Education) GNCTD, Old Secretariat, New Delhi-110054.
- 2 Manager, Durga Public School located at RZ-28 & 31/184 Durga Park, Street No.2, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	Durga Public School, RZ-28 & 31/18-1, Durga, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground floor only)		
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/286 Dated 28.2.2014		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	24.1.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Vipin Panwar (Manager)		
9	Year of construction	1998, 2006		
10	Applicant's letter No.	Nil 2.1.2018	(Plot No. 28 comprised of basement , ground + one upper floor & Plot No. 31 Ground & one upper floor Ground plus One upper floor.	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E letter dated 1.3.2011/ letter dated 28.2.2014	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	5 Mtrs.	MR being old case
	2) Gate width	4.5 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A	School at ground floor	N/A
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	School at ground floor	N/A
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	One	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	.93 to .95 Mtr.	MR being old case
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	School at ground floor	N/A
	upper floors		Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	4 Nos. ABC & CO2 ISI Marked	4 Nos.	MR
	Types		ABC & CO2	MR
	ISI marking		ISI Marked	MR

	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/8

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire extinguisher provided near electric Meter	MR		

Fire protection systems provided in the building were checked and found functional at the time of inspection .

keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required as per D O E letter dated 1.3.2011, renewal of FSC issued vide letter no. F6/DFS/MS/School/2014/SZ/286 dated 28.02.2014 is recommended.

Accordingly DFA is put up for your approval and signature please.

Sury
29/1/18
S.P. Bhardwaj
ADO (Dwarka)

D.O. No

28/1/2018

42/20/800
29/1/2018

DCFO (S2)



20/1

1575/CFAS2
22/9/2

CFO (S2) M.S cell 27/2

FT is put up for signature please.

CFAS24

M.S cell 27/2

Sury
29/1/18