

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/NDZ/2018

1EH/256

Dated:

15/02/18

FIRE SAFETY CERTIFICATE

Certified that the M/S Biknervalva Foods Pvt. Ltd., at ZB-9,10 & 11 / 487 G.T. Road, Dilshad Garden Industrial Area, New Delhi, running only on ground level owned / occupied by Biknervalva. The building comprised of basement, ground plus two upper floors. The building was inspected by the officer concerned of this department on 02/1/2018 in the presence of Sh. pushpender (Manager) of the premise and found that the Assembly building have complied with the Fire prevention and Fire safety requirements in accordance with the rules . The Fire Safety Certificate under rule 35 unless renewed under rule 36 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group "D" "Assembly Building" with effect from 15/02/18.. for a period of three years, subject to conditions printed overleaf.

Issued on.....15/02/18.....at New Delhi by

13/2
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The health officer ,
EDMC (PHD), Shadhra South Zone
Delhi-110092.
2. Biknervalva Foods Pvt. Ltd.,
ZB-9,10 & 11 / 487 G.T. Road,
Dilshad Garden Industrial Area, New Delhi.

o/c
f

INSPECTION REPORT

1. Name & address of the building : Biknervalva Foods Pvt. Ltd., ZB-9,10 & 11/487, G.T.Road, Dilshad Garden, Shahdara, Delhi.
2. Building is comprised of : B+G+II upper floors
3. Type of Occupancy : Assembly (Restaurant) on ~~ground~~ ^{ground} level
4. Type of Case : New
5. Details of Previous FSC : NIL
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 02/01/18,
8. Name of the Inspecting Officers: : DO. F. Brown
9. Name of the designation of Officer :
from the building side : Sh. Pushpender (Manager)
10. Year of Construction : 2005
11. Applicant's letter No : dt. 05.12.17

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	120 m wide main road	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	N/A	N/A	N/A
	Basement	02	01 + 01 door open on main road	MR
	B. Width of Staircases			
	Upper Floor	N/A	N/A	N/A
	Basement	02	1.25 M +10 M wide gate open on main road	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 Mtrs.	2no's 2M, & 01no's 1.5 M	MR
3	Compartmentation.			
	Fire check door	N/A	N/A	N/A
	Sealing of electrical shafts	Required	Sealed	MR
	Fire rating of shaft door	2 hrs.	2 hrs.	MR
	Water curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	Basement	N/A	N/A	N/A
	Upper floor	N/A	N/A	N/A
5.	Fire Extinguisher			
	Total numbers	06 Nos.	08 Nos.	MR
	types	ABC type & Co2	ABC type & Co2	MR
	ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of 2 nd floors	01 nos.	01 nos.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat or Smoke	smoke	MR
	Location of main panel	G. Floor	G. Floor	MR
	Location of repeater panel	NA	NA	NA
	Alternate source of power	Battery & DG Set	Provided	MR
	Hooters	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	Basement	Require	Provided	MR
	Upper floor	N/A	N/A	N/A
	sprinkler above false ceiling	Require	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	01 nos.	01 nos.	MR
	Hose box each floor	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 mtrs	40 mtrs	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

h


N/3

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	25,000 Ltrs.	25,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A

The Fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping In view compliance of the minimum standards of Fire prevention and Fire Safety measured as required under the rules .

The Fire safety certificate issued under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Signature of the Inspecting Officer

Name : F.BROWN

Designation : DO