

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2018/SZ/257

Dated: 15/02/18

FIRE SAFETY CERTIFICATE

Certified that **Govt. Boys Senior Secondary School No-3, Sarojini Nagar, New Delhi- 110023**, comprised of **Ground plus two upper floors** was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/1352 dated 30/10/2014. The school premises was re-inspected by officer concerned of this department on 12/01/2018 in presence of Mr. H.L. Meena (HOS) and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 15/02/18..... at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Head of School, Govt. Sr. Sec. School No-3, Sarojini Nagar, New Delhi- 110023
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Govt. Boys Senior Sarvodaya School No-3, Sarojini Nagar, New Delhi-110023 (1719005)		
2	Type of Occupancy	Educational Building, Group-B		
3	Building Comprised of	Ground plus two upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/1352 Dated 30-10-2014		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	12-01-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. H.L. Meena (HOS)		
10	Year of construction	1956		
11	Applicant letter No.	503/GBSSS/2017 Dated 13/12/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	Required	Two	MR
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.			
	b) Width of Staircase	1.5m / 0.75m	1.60m each	MR
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor			
	c) Protection of exits	-NA-	-NA-	-NA-
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization			
	d) No. of continuous staircase to terrace	Required	One	MR
		-NA-	-NA-	-NA-
	e) Width of corridor	1 mtr	Provided	MR
	f) Door size			
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	14	19 No's	MR
	• Types	ISI marked	CO2- 14, ABC-05	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.		Two	MR
	• Length of hose-reel hose.	Hose-reels	30 mtr	MR
	• Nozzle Diameter		5 mm	MR

Govt. Boys Senior Secondary School, Sarojini Nagar, New Delhi-110023

N/ 9

19.	Fire Control Room.	• Detector system panel.	-NA-	-NA-	-NA-
		• Flow switch panel.	-NA-	-NA-	-NA-
		• PA system panel.	-NA-	-NA-	-NA-
		• Battery backup.	-NA-	-NA-	-NA-
		• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.		-NA-	-NA-	-NA-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under DOE circular, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2014/SZ/1352 dated 30/10/2014, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

R.N. Singh
17/1/18

Signature of the Inspecting Officer

Name : R.N. Singh

Designation: ADO (BCP)



Govt. Boys Senior Secondary School, Sarojini Nagar, New Delhi-110023

DO (SD)

Anil Kumar
18/1/18