

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.

No. F.6/DFS/MS/Cinema/2018/SZ/ 258

Dated: 15/2/18

FIRE SAFETY CERTIFICATE

Certified that the **Janak Cinema (Audi 01 to 04)** located at C-Block, Community Centre, Janak Puri, New Delhi-110058, comprised of first and second floor of a building having basement, ground plus two upper floors owned/ occupied by M/s Skipper Properties Pvt. Ltd. was inspected by the officers concerned of this department on 13.02.2018 in the presence of Sh. Harvinderpal Singh (Owner) and found that the owner/occupier have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Audi 01 to 04**) is fit for occupancy Group-D (Assembly Building) w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....15/2/18.....at New Delhi.


(VIPIN KENTAL)
CHIEF FIRE OFFICER

S.D.M. Dwarka
15/2/18

Copy to:-

1. The Manager,
Janak Cinema/Commercial Building, C-Block,
Community Centre, Janak Puri, New Delhi-110058.
2. The S.D.M(Dwarka),
South west district, SDM office complex,
Tura Mandi, Najafgarh, New Delhi-43

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Seating arrangements shall be maintained as per Cinematograph Act 2008.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement shall be used as per the building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/10

Audi 01 to 04 is located at first & second floor of a building comprised of basement, ground floor plus two upper floors.

INSPECTION REPORT

1. Name & address of the building : Janak Cinema, C-Block, Community Centre, Janak Puri, New Delhi-110058
2. Type of Occupancy : Group D (Assembly Building)
3. Type of Case : New case
4. Details of Previous NOC : N.A
5. Fire Safety directives letter No : F.6/DFS/MS/BP/Cinema/2011/102 dated 20.01.2011
6. Date of inspection : 13.02.2018
7. Name of Inspecting Officer : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Harvinderpal Singh (Owner)
9. Year of Construction : 2016-2017
10. Applicant's letter No. : F./SDM/DW/UC/2018/7077 dated 01-02-2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 no.'s (GF to Terrace) & 04 no.'s (Audi to GF)	Provided	MR
		02 No's	Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	200 cms each	Provided	MR
		200 cms each	Provided	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required	Provided	MR
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Provided (02 no.'s)	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	200 cms (02 no.'s/Audi)	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		Required	Provided	MR
		02 hrs	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	Required Mechanical ventilation system	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers on each floor • Types • IS marking 	20 no.'s	Provided	MR
		ABC/CO ₂ /W CO ₂ type	Provided	MR
		ISI marked	Provided	MR
6.	First-Aid Hose Reels			

4. Details of Previous NOC : N.A
 5. Fire Safety directives letter No : F.6/DFS/MS/BP/Cinema/2011/102 dated 20.01.2011
 6. Date of inspection : 13. 02.2018
 7. Name of Inspecting Officer : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
 8. Name and designation of officers
 From the building side : Sh. Harvinderpal Singh (Owner)
 9. Year of Construction : 2016- 2017
 10. Applicant's letter No. F./SDM/DW/UC/2018/7077 dated 01-02-2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 mtrs 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s (GF to Terrace) & 04 no.'s (Audi to GF)	Provided	MR
		02 No's	Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	200 cms each 200 cms each	Provided Provided	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	Required	Provided (02 no.'s)	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	200 cms (02 no.'s/Audi)	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required 02 hrs N/A Required	Provided Provided Provided N/A Provided	MR MR MR N/A MR
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Mechanical ventilation system Required	Provided Provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers on each floor Types IS marking 	20 no.'s ABC/CO ₂ /W CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each audi Length of hose reel hose Nozzle diameter 	Two 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			

2/11

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/Heat	Provided	MR
		In FCR	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Entire building	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per audi Hose Box 	100 mm	Provided	MR
		Two	Provided	MR
		Two	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Four	Provided	MR
		Four	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 			
		2280 LPM	Provided	MR
		60 mtrs	Provided	MR
		Two	Provided	MR
		180 LPM (02 no.'s)	Provided	MR
		60 mtrs	Provided	MR
		2280 LPM	Provided	MR
		60 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		900 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,50,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR


9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per audi 	Two	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Two	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	Four	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Four	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	2280 LPM	Provided	MR
		60 mtrs	Provided	MR
		Two	Provided	MR
		180 LPM (02 no.'s)	Provided	MR
		60 mtrs	Provided	MR
		2280 LPM	Provided	MR
		60 mtrs	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Required	Provided	MR
		900 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,50,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply			
		Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

N/12


Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Manually operated CO ₂ flooding system	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


13/2/18

Signature of Inspecting Officer
Name:- M.K. Chattopadhyay
Designation:- Divisional Officer


13/02/2018

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer