

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/GH/2018/NDZI/ 257

Dated 15/2/18


FIRE SAFETY CERTIFICATE

Certified that the M/s L'elegant Banquet Hall (Star Height) Plot no. 1/A, running on ground level in Star City Mall, at Mayur Vihar -1 Delhi -91, comprised of basement, ground, plus two upper floors respectively owned / occupied by M/s L'elegant Banquet Hall,. The Premises was inspected by the officer concerned of this department on 10.2.18 in the presence of Sh. Naddem Malik (Manager) and found that the Assembly building have deemed complied with the Fire prevention and Fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the Banquet hall is running on ground floor only with effect from 15/2/18 for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 15/2/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-
Deputy Health Officer,
Shadhra South zone,
East Delhi Municipal Corroboration Delhi.

O/C

13/2

CONDITIONS

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s L'elegant (Star Height) Banquet, Hall Plot No. 1/A, at ground level Star City Mall Mayur Vihar -1 Delhi - 92.
2. Building is comprised of : Basement, Ground plus two upper floors ,
3. Type of Occupancy : Assembly, (Banquet hall at Ground level)
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : NBC Part-IV,
7. Date of Inspection : 10. 02.2018
8. Name of the Inspecting officers : Francis Brown (DO)
9. Name and designation of officer from the building side : Nadeem Malik (Manager)
10. Year of construction : 2004,
11. Applicant's letter No : DHO/Shd(s)/2018/85 dated 18/2/18.

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 m	06 m	MR
	• Gate width	4.5	6m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 m	02 m (2) and 1.83(4)	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	sealed	MR
	• Fire rating of shaft door	02hrs	02hrs	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basement	30a/c per hrs	provided	MR
	• Upper floor	12 a/cper hrs	provided	MR
5	Fire Extinguishers			
	• Total numbers	06 nos.	08 Nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

* Basement & upper floors are not part of the Banquet Hall. There are total six no of doors provided in the hall 02 no's of door size 2m and 04 no door size is 1.83 m. wide each and every doors are open on ground floor.

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	02 no.	02 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat/smoke	provided	MR
	• Location of main panel	Control Room	provided	MR
	• Location of repeater panel	Security room	provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter's location	Different location	Different location	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	Provided in entire basement	NA
	• upper floor			
	• sprinkler above false ceiling	Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	Provided	NA
	• Hose box	NA	Provided	NA
13	Pumping Arrangements.	Provided for entire mall building		
	• Ground Level	NA	Provided	NA
	• Discharge of main pump	450 lpm	4500	MR
	• Head of main pump	NR	Provided	NR
	• Number of main pumps	NR	Provided	NR
	• Jockey pump out put	NR	Provided	NR
	• Jockey pump head	NR	Provided	NR
	• Standby pump out put	NR	Provided	NR
	• Standby pump head	NR	Provided	NR
	• Auto starting /manual stopping	NR	Provided	NR
	• Pump house access	NR	Provided	NR
	• Terrace Level	All above pumps are on terrace		
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	Provided	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NR	2,000ltrs	NR
	• Draw-off connection	NR	Provided	NR
	• Fire service inlet	NR	Provided	NR
	• Access to tank	NR	Provided	NR
	• Overhead Tank capacity	10,000ltrs	2,50,000ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A ✓
	• Pressurization of Lift lobby	N/A	N/A	N/A ✓
	• Communication in lift car	N/A	N/A	N/A ✓
	• Firemen's grounding switch	N/A	N/A	N/A ✓
	• Lift Signage	N/A	N/A	N/A ✓
17	Standby power supply	Required	1500,kvs	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A ✓
	• Location	N/A	N/A	N/A ✓
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A ✓
	• Flow switch panel	N/A	N/A	N/A ✓
	• PA system panel	N/A	N/A	N/A ✓
	• Battery backup	N/A	N/A	N/A ✓
	• Building Floor Plans	N/A	N/A	N/A ✓
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on Fire prevention and Fire safety measures as required under the Rules. It is recommended to grant the Fire Safety Certificate under the rules 35, of the Delhi Fire Service Rule 2010.

* The Banquet hall is running inside the Star city Mall. Hence Fire safety arrangements and exits meeting the all requirements.

Handwritten signature and date
 2/11/18.