

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *F6/DFS/MS/2018/NDZ/302*

Dated: *26/2/18*

FIRE SAFETY CERTIFICATE

Certified that the Salwan Public School, Mayur Vihar-Ph-III, Delhi-96, comprised of ground floor plus three upper floors was granted Fire Safety Certificate by this department vide Letter No- F6/DFS/MS/School/2014/NDZ/1512 Dated 03/12/14. The School building was re-inspected by the officer concerned of this department on 12/02/18 in the presence of Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the building is fit for occupancy Group B "Educational Building" with effect from *26/2/18*..... renewed for a period of three years, subject to conditions printed overleaf.

Issued on.....*26/2/18*.....at New Delhi by

Vipin Kental

(Vipin Kental)

Chief Fire Officer

d/cfu

To,

The Principal
Salwan Public School, Mayur Vihar-Ph-III, Delhi-96

Copy to:-

The Joint Director of Education
(Land & Estate)
Directorate of Education, Lucknow Road, Delhi -54

INSPECTION REPORT

1. Name & address of the building : Salwan Public School, Mayur Vihar-Ph-III, Delhi-96
2. Building is comprised of : G+3
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/School/2014/NDZ/1512 Dated 03/12/14
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 12/02/18
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer
from the building side : Principal
10. Year of Construction : 2004
11. Applicant's letter No : S.P.S/MV/17/ 2709 dated 29/12/17

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12m	15 m	MR
	Gate width	4.5 m	4.5 m	MR
	Width of internal road	05 m	05 m	MR
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	1.7 m, 1.5m,	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.	2 no	MR
g. Width of Corridor	1.5 m	2 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12a/c per hour	N.A.	N.A.

5.	Fire Extinguisher			
	Total numbers	20 no.	20 no.	MR
	types	ABC+ CO ₂	ABC+ CO ₂	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	02 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
9	Public address System.	N.A.	Provided	MR
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	100 mm	MR
	Number of hydrants each floor	N.A.	2 no.	MR
	Hose box each floor	N.A.	2 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	60,000 ltrs	MR
	Draw-off connection	N.A.	Provided	MR
	Fire service inlet	N.A.	Provided	MR
	Access to tank	N.A.	Provided	MR
	Overhead Tank capacity	10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/School/2014/NDZ/1512 Dated 03/12/14 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

R. K. Yadav
12/12/2018

Signature of the Inspecting Officer

Name R.K. Yadav

Designation ADO (LN)

Submitted for approval plan.

DO (EAST)

DY CPO/NDZ.

for copy
15/12/18.

380/CFO/NDZ
22/2.

[Signature]
19/12

FTM.

ve
22/2

C. FA.

M. SCEN