

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No.F6/DFS/MS/School/2018/ 309



Dated: 27/2/18

**FIRE SAFETY CERTIFICATE**

Certified that the **Ramjas Sr. Sec. School No.1** located at **Darya Ganj, New Delhi - 110002** comprised of **Ground + 1 upper floor only** owned / occupied by **Ramjas Sr. Sec. School** was granted FSC by this department vide letter No.F6/DFS/MS/School/2015/NDZ/280 dated **27/02/15**. The premises was re-inspected by the officer concerned of this department on **02/02/18** in the presence of **Mr. Rajesh Sansanwal ( Principal)** and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03. 2011 that the building is fit for occupancy, class **B "Educational Building"** with effect from ...**27./2./18**.....for a period of three years, subject to conditions mentioned below.

Issued on .....**27./2./18**..... at New Delhi.

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
Ph.- 011-23412225

Copy to:- (1) The Principal  
Ramjas Sr. Sec. School No.1, Darya Ganj, New Delhi -110002.   
(2) Director of Education,  
GNCTD,  
Old Secretariat, Delhi. 

**Conditions for the validity of fire safety certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
4. All the staff members must know the correct method of operation of fire fighting system.
5. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
6. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

462

**INSPECTION REPORT**

- |                                      |  |
|--------------------------------------|--|
| 1. Name & address of the building :- | Ramjas Sr. Sec. School No.1, Darya Ganj,<br>New Delhi -110002. |
| 2. Type of occupancy:-               | Group – B Education Building.(Gr.+ 1)                          |
| 3. Type of case:-                    | Renewal.   |
| 4. Details of previous NOC:-         | No.F6/DFS/MS/School/2015/NDZ/280 dated<br>27/02/15.            |
| 5. Fire safety directives No.-       | N/A  |
| 6. Date of inspection:-              | 02/02/18   |
| 7. Name of the inspecting officer:-  | .D.O. Gurmukh Singh.   |
| 8. Name & designation of officer:-   | From the building side:-<br>Mr. Rajesh Sansanwal (Principal)   |
| 9. Year of construction:-            | 1912   |
| 10. Applicant's letter No:-          | Nil- Dated 12/12/17.   |

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As per Education Deptt Circular	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	6 mtr.	06 mtr	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	01 no.	02 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	150 cms.	170 & 75 cms.	MR(old case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	12 Nos.	12Nos.	MR
	2) Types	ABC & co2	ABC & co2	MR

h

	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A

21-9

	d) Over head tank capacity	N/A	N/A	N/A
15.	<b>Exit Signage.</b>	N/A	N/A	N/A
16.	<b>Provision of Lifts.</b>	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:-</b>			Fire Buckets

The fire protection system provided in the school were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/School/2015/NDZ/280 dated 27/02/15, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

*Gurmukh Singh*  
Gurmukh Singh  
Divisional Officer

Dy CRO (NDZ) *[Signature]*

428/Cfo NDZ  
12/2/26/2  
Recd. today.  
*[Signature]*  
22/2

C.F.O. - M. Scell FTM.  
*[Signature]*  
12/2

F.T. letter is put up for sign. P.O.

*[Signature]*  
22/2/18

C.F.O.