

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI


No.F6/DFS/MS/School/2018/WZ/ 334

Dated: 28/2/18

FIRE SAFETY CERTIFICATE

Certified that the **P.N. Memorial Public School**, Plot No. 78, Friends Enclave, Rajendera Park, Nangloi, Delhi-41. at ground floor only was issued FSC vide Letter No. **F6/DFS/MS/School/2015/WZ167 dated 05/02/15**. The premises was re inspected by the officers concerned of this department on **19.02.2018** in the presence of **Sh. Rakesh (Manager)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with the Circular No.F16/Estate/CC/Fire Safety/2011/3298/ to 3398 dated 01.03.2011 and that the premises is fit for occupancy class "Educational" Group B-I only for G.F. with effect from 28/2/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...28/2/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

1. Sh. Rakesh (Manager),
P.N. Memorial Public School, Plot No. 78, Friends Enclave,
Rajendera Park, Nangloi, Delhi-41.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **P.N. Memorial Public School**, Plot No. 78, Friends Enclave, Rajendera Park, Nangloi, Delhi-41.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2015/WZ167 dated 05/02/15
5. Fire Safety directives Letter No. : DOE 3298/3389 dated 01.03.2011
6. Date of inspection : 19.02.2018
7. Name of the Inspecting Officer : Mukesh Verma, DO (West)
8. Name and designation of Officer
from the building side : Sh. Rakesh (Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : nil Dated 01.02.2018

Ground Floor only
Total Area – 400M²
Covered Area-150M²

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298/3389 dated 01.03.2011 /NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	No basement	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA

Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2015/WZ167 dated 05/02/15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer *Mukesh Verma* 19/2/18

Name : Mukesh Verma

Designation : DO (West)

Dy. DO (W2)
CFO West
 22/2/17
 TPLS
21/2/18

DO/W FT is put up for signature please.

CFO (West)
 20/2/18
Mukesh Verma 27/2/18