

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/2018/WZ/ 335

Dated: 28/03/2018

FIRE SAFETY CERTIFICATE

Certified that the **Guru Nanak Public School, Located at, West Avenue, Punjabi Bagh, New Delhi - 110026** comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/SCHOOL/2014/WZ/1161 dated 19-07-14**. The premises was re inspected by the officer concerned of this department on **12-02-2018** in the presence of **Smt Reema Punj (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Director of Education circular no-F6/Estate/CC/Fire/Safety/2011/3298-3398 3398 Dated 01-03-11/ and that the premises is fit for occupancy class "Educational" Group B with effect from 28/2/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 28/2/18 at New Delhi.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service.


28/2/18

Copy to:-

1. The Principal,
Guru Nanak Public School, West Avenue, Punjabi Bagh, New Delhi - 110026.
Following fire safety directives must be adhered to:-
1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement if any, shall be used strictly as per building bye laws.
7. All the exit must be kept free from any obstruction.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

1. Name & address of the building: Guru Nanak Public School, Located at, West Avenue, Punjabi Bagh, New Delhi - 110026.
2. Type of Occupancy : Educational (Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2014/WZ/1161, Dated 19-07-14
5. Fire Safety directives Letter No. : Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
6. Date of inspection : 12-02-2018
7. Name of the Inspecting Officer : DO/W, ADO (WP)
8. Name and designation of Officer
from the building side : Smt Reema Punj (Principal)
9. Year of Construction : 1979
10. Applicant's letter No. : 1455 Dated 11-01-2018

No. of Students=2017
 No. of class rooms=66
 Plot area=4530.45 Sqm
 Covered area=109920Sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	3298- 3398 dated 01.03.2011	Provided at site	Remarks MR/NM/R
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided 4.6m Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 3 NA 	<ul style="list-style-type: none"> 4 Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.5m NA 	<ul style="list-style-type: none"> 2x1.51m, 1x1m, 1x1.16m NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	212cm & 148cm	MR
	f. Door Size	1m	93cm (Old Case)	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	20 nos.	Provided	MR

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	3	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	900LPM,450LPM	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank 	NA	NA	NA
		NA	NA	NA
		NA	Provided	NA
		NA	NA	NA

16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/SCHOOL/2014/WZ/1161 dated 19-07-14 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Sh. Mohesh Verma
 Designation DO/W

Signature of the Inspecting Officer
 Name Vedant Singh
 Designation AO/WP

Dy. (AO/WZ)
CFO West 22/2/18 FTPS

AO/WP
 Sir 84 letter is put up for sign plz.
CFO 28/2/18