

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F6/DFS/MS/2018/M.02/301

Dated 26/2/18

FIRE SAFETY CERTIFICATE

Certified that the Gopal Vatika Banquet Hall, at Plot no. 603 to 612 Mandoli Road, Shahdara, Delhi, Comprised of ground floor only owned/occupied by M/s Gopal Vatika Banquet Hall was granted FSC vide letter No. F6/DFS/MS/BNQT/2015/NDZ/96 dt 20/01/15. The Premises was re-inspected by the officer concerned of this department on 06/02/2018 in the presence of **Mr. Rakesh Sharma** (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the building is fit for occupancy class "D-Assembly building (Banquet Hall) with effect from ...26/2/18.... for a period of **three years** , subject to conditions printed overleaf.

Issued on.....26/2/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer



To,

Mr. Rakesh Sharma (Manager)
Plot no.603 to 612 Mandoli Road,
Shahdara, Delhi.

Copy to-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone, Delhi.

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
- 6 This FSC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7 Basement shall be used as per BBL
- 8 The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
- 9 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

NIS

1. Name & address of the building : Gopal Vatika Banquet Hall, at Plot no.603 to 612 Mandoli Road, Shahdara, Delhi.
2. Building is comprised of : Ground floor only
3. Type of Occupancy : Assembly(Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/BNQT/2015/NDZ/96 dt 20/01/15
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 06/02/2018
8. Name of the Inspecting Officers: : R.K.Yadav ADO
9. Name of the designation of Officer from the building side : Mr.Rakesh Sharma (Owner)
10. Year of Construction : 2009
11. Applicant's letter No : Nil Dated 16/01/18

Sr. no.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			MR/NMR
	Road width	06 m	30 m	MR ✓
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	N/A	1no for terrace	MR ✓
	Basement	N/A	N/A	N/A
	b. Width of Staircases			
	Upper Floor	N/A	1.25 m	MR
	Basement	N/A	N/A	N/A
	c. Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2 m	2 m each	MR ✓
i. No. of door	2 No	4 Nos	MR ✓	
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR ✓

Fire Extinguisher			
• Total numbers	04 nos.	06 Nos.	MR
• Types	CO ₂ & ABC	Provided	MR
• ISI marking	ISI marked	Provided	MR
First-aid-Hose Reels.			
Total numbers of each floor	01 no.	Provided	MR
Length of hose reel hose	30 m	Provided	MR
Nozzle diameter	5 mm	Provided	MR
Automatic fire detection and alarming system.			
Type of detectors	N/A	N/A	N/A
Location of main panel	N/A	N/A	N/A
Location of repeater panel	N/A	N/A	N/A
Alternate source of power	N/A	N/A	N/A
Hooter's location	N/A	N/A	N/A
MOEFA	Required	Provided	MR
Public address System.	N/A	N/A	N/A
Automatic Sprinkler System.			
basement	N/A	N/A	N/A
upper floor	N/A	N/A	N/A
sprinkler above false ceiling	N/A	N/A	N/A
Internal Hydrants			
size of riser/down-comer	100 mm	Provided	MR
Number of hydrants per floor	1 no.	Provided	MR
Hose Box	1 no.	Provided	MR
Yard Hydrants.			
Total number of hydrants	N/A	N/A	N/A
Hose Box	N/A	N/A	N/A
Pumping Arrangements.			
• Ground Level			
➤ Discharge of main Pump	N/A	N/A	N/A
➤ Head of Main Pump	N/A	N/A	N/A
➤ Number of main pumps	N/A	N/A	N/A
➤ Jockey pump out put	N/A	N/A	N/A
➤ Jockey pump head	N/A	N/A	N/A
➤ Standby pump out put	N/A	N/A	N/A
➤ Standby pump Head	N/A	N/A	N/A
➤ Auto Starting /Manual stopping	N/A	N/A	N/A
➤ Pump House Access	N/A	N/A	N/A
• Terrace Level			
➤ Discharge of pump	450LPM	Provided	MR
➤ Head of the Pump	40 M	Provided	MR
➤ Power supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	10,000 Liters	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply.	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The fire safety certificate issued vide letter no. F6/DFS/MS/BNQT/2015/NDZ/96 dt 20/01/15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
8/2/2018

Signature of the Inspecting Officer
Name :-R.K.Yadav
Designation :-ADO(LN)

DO(ED) *submitted for approval plan.*

DYCP/MDU

for of
8/2/18

325/cfomr
19/c/22/2

-CF/P.
M-scell FT M.

14/11

Env, FT Letter & put up for signature please