

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No.F6/DFS/MS/School/2018/ 310



Dated: 27/2/18

FIRE SAFETY CERTIFICATE

Certified that the **D.A.V. Public School** located at **Darya Ganj, New Delhi-110002**, comprised of **Ground + 1 upper floor only** owned / occupied by **D.A.V. Public School** was granted FSC by this department vide letter No.F6/MS/DFS/2007/611 dated **01/13/2007**. The premises was re-inspected by the officer concerned of this department on **02/02/18** in the presence of **Mr. Ramakant Tiwari & Mrs. Komal Behl** and found that in one building two schools are fun i.e **D.A.V. Public primary School of ground floor in 14 rooms & on first floor of the building H.M.D.A.V. Sr. Sec. School**. The premise have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03. 2011 that the building is fit for occupancy, class **B "Educational Building"** with effect from27/2/18.....for a period of three years, subject to conditions mentioned below.

Issued on27/2/18..... at New Delhi.


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service
Ph.- 011-23412225

- Copy to:- (1) The Principal
D.A.V. Public Primary School, Darya Ganj, New Delhi-110002. 
(2) The Principal
H.M.D.A.V. Sr. Sec. School, Darya Ganj, New Delhi- 110002. 
(3) Director of Education,
GNCTD,
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
4. All the staff members must know the correct method of operation of fire fighting system.
5. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
6. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.the form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

- | | |
|--------------------------------------|---|
| 1. Name & address of the building :- | D.A.V. Public Primary School & H.M.D.A.V Sr. Sec. School Darya Ganj, New Delhi-110002. |
| 2. Type of occupancy:- | Group – B Education Building.(Gr.+ 1) |
| 3. Type of case:- | Renewal. |
| 4. Details of previous NOC:- | No.F6/MS/DFS/2007/611 dated 01/03/2007. |
| 5. Fire safety directives No.- | N/A |
| 6. Date of inspection:- | 02/02/18 |
| 7. Name of the inspecting officer:- | .D.O. Gurmukh Singh. |
| 8. Name & designation of officer:- | |
| From the building side:- | Mr. Ramakant Tiwari & Mrs. Komal Behl |
| 9. Year of construction:- | Old |
| 10. Applicant's letter No:- | DAVPPS/Gen/652/2017-18 Dated 12/01/18. |

Old Case

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | As per Education Circular | Provided at site | Remarks MR/NMR |
|-----------|---|---------------------------|------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 6 mtr. | 06 mtr | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 01 no. | 02 nos. | MR |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | 125 cms. | 125 cms. each | MR |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | N/A | N/A | N/A |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 1 mtr. | 1 mtr. | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 a/c per hour | N/A | N/A |
| | 2) Upper floors | 12 a/c per hour | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | 12 Nos. | 12Nos. | MR |
| | 2) Types | ABC & co2 | ABC & co2 | MR |
| | 3) ISI marking | Required | Provided | MR |

h

| | | | | |
|------------|---|-----|-----|-----|
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | N/A | N/A | N/A |
| | 2) Length of hose reel hose | N/A | N/A | N/A |
| | 3) Nozzle diameter | N/A | N/A | N/A |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | N/A | N/A | N/A |
| | b) Head of pump | N/A | N/A | N/A |
| | c) Power supply | N/A | N/A | N/A |
| | d) Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | N/A | N/A | N/A |

| | | | | |
|-----|--|-----|-----|--------------|
| 15. | Exit Signage. | N/A | N/A | N/A |
| 16. | Provision of Lifts. | N/A | N/A | N/A |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any:- | | | Fire Buckets |

The fire protection system provided in the school were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/MS/DFS/2007/611 dated 01/13/07, renewal under rule35 of the Delhi Fire Service rules 2010, is recommended.

Gurmukh Singh
7/2/18
Gurmukh Singh
Divisional Officer

DyCSO (NDZ)
[Signature]

C.F.O.

The name of both the schools should also be mentioned here in note.

[Signature]
DyCSO (NDZ)

[Signature]
12/2/18

D.A.T.

The names of both the schools already mentioned in inspection report.