

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2018/ *w21 298*

Dated: *23/02/2018*

FIRE SAFETY CERTIFICATE

Certified that the **Castle's Barbeque (A unit of Parks Jubilant Food and Hospilities)** located at **Shop No.TF-2C, Pacific Mall, Najafgarh Road, Khayala, New Delhi** was issued FSC vide Letter No. F6/DFS/MS/EH/2012/2819 (Issued to Haldiram running in same shops) dated 01-08-2012 and FSC to mall is issued vide letter no. F6/DFS/MS/2017/WZ/577 dated 21-04-2017. The premises was re inspected by the officers concerned of this department on 19-02-2018 in the presence of Mr. Amit Kumar (Restaurant Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from *23/2/18* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on*23/2/18*..... at New Delhi by.

Atul Garg
(Atul Garg)

Chief Fire Officer
Delhi Fire Service.

Copy to:

1. Castle's Barbeque, Shop No.TF-2C, Pacific Mall, Najafgarh Road, Khayala, New Delhi.
2. Dy. Health Officer,SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi - 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Recd.
(A)

Pacific Mall, Najafgarh Road, Khayala, New Delhi

2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2012/2819 dated 01-08-2012(Issued to Haldiram running in same shops)
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 19-02-2018
7. Name of the Inspecting Officer : DO (West) & ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Amit (Manger)
9. Year of Construction : 2015
10. Applicant's letter No. : D-2831/HD/WZ dated 13-11-2017 *partly lettered no nil dated nil.*

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 mtrs 5 mtr 6m	60m Provided 6mtr 12 m	MR MR MR
2.	Number, width, Type & Arrangements of exits: common with the mall			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2	Provided by mall	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	Required NA	170cm & 104 cm NA	MR (Old case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	Required	103cm, Provided	MR(Old Case)
	f. Door Size	2m & 1m	106cm & 200cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA 12 a/c per hour	NA Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 nos. each type DCP & CO ₂	06 Provided Provided Provided	MR MR MR

6.	First Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Not Applicable	Not Applicable	Not Applicable
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants: Common with the mall			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements: Common with the mall			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	Common with the mall	NA
		NA	Common with the mall	NA
		NA	Common with the mall	NA
		NA	Common with the mall	NA
		NA	Common with the mall	NA
		NA	Common with the mall	NA
		NA	Common with the mall	NA
		NA	Common with the mall	NA
		NA	Common with the mall	NA
		900 lpm	Common with the mall	MR
		40 m	Common with the mall	MR
		Required	Common with the mall	MR
		Required	Common with the mall	MR
14.		Captive water Storage for fire fighting: Common with the mall		
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	2,00,000 litres	NA
		NA	Provided	NA
		Required	Provided	MR
		NA	Provided	NA
		10, 000 litres	30, 000 Litres	MR
		Provided		

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2012/2819 dated 01-08-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Udai Vir Singh

Name

Designation

ADD/WP

Designation

Date

20/6/18

~~Dr. GPO (H2)~~ P. NOC is not available in the file

Dr. GPO (H2) Sir, file is attached.

Dr. GPO (H2)

S.A. West

22/2/18

22/6/18

21/7/18