

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/*School/WZ/2018/347*

Dated: *28/2/2018*

**FIRE SAFETY CERTIFICATE**

Certified that **Vidya Bharti Public School, at Sector – 15, Rohini, Delhi 110085** comprised of **Ground + Three Upper Floors** owned/occupied by **Vidya Bharti Public School** was issued fire safety certificate vide letter no. **F-6/DFS/MS/School/2014/WZ/1421** dated **19/11/2014**. The premises was re-inspected by the officer from this department on dated **19/02/2018** in the presence of **Mrs. Sovanika Pal (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition and there is no additional construction. The premises have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and building / premises is fit for occupancy under **Education Class** with effect from **28/2/2018** for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on *28/2/18* at New Delhi by

*(Signature)*  
(Atul Garg)

Chief Fire Officer

Ph: 011-23414250

**Copy to:**

1. The Principal, Vidya Bharti Public School, at Sector – 15, Rohini, Delhi 110085
2. The Director of Education, Old Secretariat, Delhi

### INSPECTION REPORT

1. Name & address of the building : Vidya Bharti School, Sector-15, Rohini, Delhi-110085
2. Type of Occupancy : **Educational** (G+3)
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/School/2014/WZ/1421 dated 19/11/2014
5. Fire Safety directives letter No : Director of Education 17/01/2005
6. Date of inspection : 19/02/2018
7. Name of the Inspecting Officers : ADO ( RN)
8. Name and designation of officers  
from the building side : Mrs. Sovanika Pal (Principal)
9. 9. Year of Construction : 1992-93
10. 10. Applicant's letter No. : VBS/DFS/10866/18 dated 10/01/2018

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 m	6 m	M/R
	• Gate width	5 m	5 m	M/R
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	04	04	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 m	1.5 m each	M/R Old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	04	04	M/R
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	01 mtr	01 mtr	M/R

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	18 ISI marked	18 08ABC, 07 WCO2 & 03 CO2 Yes	M/R M/R M/R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	03 30 m 5 mm	Provided Provided Provided	M/R M/R M/R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	<b>MOEFA</b>	Required	Provided	M/R
9	<b>Public Address System.</b>	Required	Provided	M/R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	4'' 03 03	Provided Provided Provided	M/R M/R M/R
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A

13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>			
		450 LPM	Provided	M/R
		40 m	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		180 LPM	Provided	M/R
		40 m	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		25000 ltr	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		5000 ltr	Provided	M/R
15	<b>Exit Signage.</b>	Required	Provided	M/R
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The party has complied all shortcomings removed.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/School/2014/WZ/1421 dated 19/11/2014 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*14/2/12*

Signature of the Inspecting Officer

Name :Rajesh Kumar

Designation: Asstt. Divisional Officer

*By CF/WZ*  
*28/1/18*  
*FTM*

*As approved, F.T. letter is put up for your signature pl.*

*14/2/12*

*CF/WZ*  
*28/1/18*

*mu*