

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/2018/ NDZ/320

Dated : 27/2/18

FIRE SAFETY CERTIFICATE

Certified that the **Palika Kendra** located at **Parliament Street, New Delhi** comprised of **2Basement + Ground + 19 Upper floors** owned/occupied by NDMC, was granted FSC by this department vide letter No.F6/DFS/MS/2014/NDZ/267 dated **25/02/14**. The premises was re-inspected by the officer concerned of this department on **01/02/18** in the presence of **Sh. Sajjan Kumar (Fire Officer)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Business Class D-3 with effect from ~~-----~~ 27/2/18 for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 27/2/18 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Sh. Sajjan Kumar (Fire Officer),
Fire Department, NDMC,
Palika Kendra, New Delhi – 110001.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/26

INSPECTION REPORT

1. Name & address of the building : Palika Kendra, Parliament Street , New Delhi
 2. Type of occupancy : Business Building (2B + Gr. 19 Upper floor)
 3. Type of case:- : Renewal
 4. Details of previous FSC : F6/DFS/MS/2014/NDZ/267 dated 25/02/2014
 5. Fire safety directives No. : 12 Points
 6. Date of inspection:- : 01/02/18
 7. Name of the inspecting officer : Sh. M.K. Sharma ADO/CC
 8. Name & designation of officer
 From the building side : Sh. Sajjan Kumar (Fire Officer)
 9. Year of construction : 1984
 10. Applicant's letter No : Nil dated 27/01/17

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 Mtr.	MR
	2) Gate width	06 mtr.	06 Mtr.	MR
	3) Width of internal road	4.5 & 06 mtr.	4.5 & 06 Mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	02 Nos.	02 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1 mtr.	1.40 mtr. each	NA
	2. Basements	1 mtr.	1.40 & 1.20 mtr.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	02 No	01 No	MR (Old)
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	Required	Provided	MR
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	304 Nos.	304 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	6 mm	6 mm	MR

M

N/27

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Gr. Floor	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box each floor	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1800 LPM	1800 LPM	MR
	b) Head of main pump	100 mtr.	100 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	220 LPM	220 LPM	MR
	e) Jockey pump head	100 mtr.	100 mtr.	MR
	f) Stand by pump output	1800 LPM	1800 LPM	MR
	g) Stand by pump head	100 mtr.	100 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltr.	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank			
	d) Over head tank capacity	50,000 ltr.	50,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft-7	Required	Provided	MR
	b) Pressurization of lift lobby-7	Required	Provided	MR
	c) Communication in	Required	Provided	MR

~

	lift car			
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: CO ₂ flooding system			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2017/2420 dated 18/09/2017 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/2014/NDZ/267 dated 25/02/14 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma

Designation :- ADO (CC)

~~DO (CD)~~

*Used
7/2/18*

DyCSO (NDZ)

[Signature]

CFP

M.Scell

FT/101

*U
9/2*

F.T. letter is put up for sign

*[Signature]
24/2*

*CFP (NDZ) M.Scell U
24/2*

*428/CF/NDZ
9/2/26/2*