

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2018/NDZ/ 369

Dated: 6/3/18

FIRE SAFETY CERTIFICATE

Certified that the **M/s Golden Petal Banquet Hall** running at ground & first floor of a building comprised of basement, ground plus four upper floors at 662/10, Shivpuri Main road, Delhi-51, owned/occupied by M/s Golden Petal Banquet was granted fire safety certificate vide letter no. F6/DFS/MS/BNQT/2015/NDZ/60 Dated 12/01/15. The Assembly building was inspected by officer concerned of this department on 23/02/18 in the presence of **Sh.Puneet Wadhwa** and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rule 2010 and found that the building ground & first floor is fit for occupancy Group D "Assembly Building" with effect from .....6.3.18.... for a period of **three** years, subject to conditions printed overleaf.  
Issued on.....6/3/18.....at New Delhi by

W  
6/3

(Vipin Kental)  
Chief Fire Officer

o/c/r/s

To

The Dy. Health Officer,  
EDMC Health Department, Shahdara South Zone,  
Karkardooma, Shahdara, Delhi.

Copy to:-

Sh.Puneet Wadhwa,  
662/10, old C-2 Shivpuri Main road,  
Krishna Nagar Extn., Delhi-51

## Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

115

**INSPECTION REPORT**

1. Name & address of the building : M/s Golden Petal Banquet Hall 662/10, Shivpuri Main road, Krishna Nagar Extn., Delhi-51.
2. Building is comprised of : B+G+4 (Banquet Hall running at ground & first floors)
3. Type of Occupancy : Assembly building
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/BNQT/2015/NDZ/60 Dated 12/01/15
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 23/02/18
8. Name of the Inspecting Officers: : ADO R.K.Yadav
9. Name of the designation of Officer from the building side : Sh.Puneet Wadhwa
10. Year of Construction : 2008
11. Applicant's letter No : dated 06/02/18

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement/NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	30 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 no.	3 nos.	MR
	Basement	2 nos.	2 nos.	MR
	B. Width of Staircases			
	Upper Floor	1.5 m	2.0M, 1.25 M & 1.0 m	MR
	Basement	1.25 M	1.25 M & .80 m	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	1 no.	2 nos.	MR
g. Width of Corridor	N.A	N.A	N.A	
h. Door Size	2 m	2 m	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	Required	Ventilated	MR
	Upper floor	Required	Ventilated	MR




5.	Fire Extinguisher			
	Total numbers	08 nos.	15 nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters's location	N.A	N.A	N.A
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	01 no.	01 no.	MR
	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump			
	➤ Head of the Pump	450 LPM	2 x450 LPM	MR
	➤ Power supply	40 m	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR

117

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	20,000 Liters	20,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A


The fire protection systems provided in the building were test checked and found functional at the time of inspection. Moreover the owner has also the width of second staircase from 0.80 to 1.0 Mtr. The Banquet Hall was issued FSC vide letter no. F6/DFS/MS/BNQT/2015/NDZ/60 Dated 12/01/15.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

  
 Signature of the Inspecting Officer  
 Name : R.K.Yadav  
 Designation : ADO (LN)

submitted for approval please.

DO(ED)

  
 24/2/18

384/CF/NM  
26/2

DY CFO/NM 7, on leave

EPO(NP2)

Miscell

FT for

26/2