

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/Bldg/SZ/2018/ 349

Dated: 05/03/18

FIRE SAFETY CERTIFICATE

Certified that the **Headquarter building of Central Information Commission (CIC)** situated at Old JNU Campus, Baba Gangnath Marg, Munirka, New Delhi-110687, comprised of **02 basements, Ground plus four upper floors** was inspected by officers concerned of this department on 28/02/2018 in presence of Mr. Srikant (Civil Er.) and found that the said premises /building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Business**" as above with effect from 05/03/2018 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 3010.

Issued on 05/03/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph.: 011-23412225

Copy to: -

1. Sh. S.K. Rabbani, Dy. Secretary (GA), Central Information Commission Room No. 507, 5th Floor, Baba Gangnath Marg, Munirka, New Delhi-110 067
2. The Executive Engineer (Bldg.), HQ, South M.C.D, 8th Floor, SPM Civic Centre, Minto Road, New Delhi-110 002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

Received Both
copies.


05-03-18

INSPECTION REPORT				
1	Name & Address of the Building	Central Information Commission, HQ Building, Old JNU Campus, Baba Gang Nath Marg, Munirka, ND		
2	Type of Occupancy	Business Building		
3	Building Comprised of	02 Basements, Ground + 04 upper floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.6/DFS/MS/2017/BP/255 dated 14-08-2017		
7	Date of Inspection	28-02-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Srikant (Civil Er.)		
10	Year of construction	2017		
11	Applicant letter No.	No. 20/2/2015/CIC (Bldg) (P&B) dated 12-02-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL / NBC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mts	24 mts	MR
	• Gate width	06 mts	06 mts	MR
	• Width of internal road	06 mts	06 mts	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 No's	04 No's	MR
	➤ Basement floor	02 No's	02 No's + 1 ramp	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr	2.0m x 3 & 1.5m	MR
	➤ Basement floor	1.50 mtr	2.0m, 1.5m + 4m ramp	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	Required	4 No's	MR
	e) Width of corridor	1.8m	Provided	MR
	f) Door size	1.5m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	12 ACPH	Provided	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	50 No's	58 No's	MR
	• Types	ABC / Co2	ABC-28, Co2-28	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	2 No's	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

7	Automatic Fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke / Heat	Smoke & Heat	MR
		Required	Ground floor	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	all floors	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		2 No's	Provided	MR
		2 No's	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	4 Nos.	Provided	MR
		4 Nos.	Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto starting/manual stopping. Pump House Access Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 			
		2280 LPM	2280 LPM	MR
		80 m	80 m	MR
		One	One	MR
		180 LPM	180 LPM	MR
		80 m	80 m	MR
		2280 LPM	2280 LPM	MR
		80 m	80 m	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	2,00,000 Ltr.	2,00,000 Ltr.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltr.	10,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area	Not required		
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

19.	Fire Control Room.	• Detector system panel.	Required	Provided	MR
		• Flow switch panel.	Required	Provided	MR
		• PA system panel.	Required	Provided	MR
		• Battery backup	Required	Provided	MR
		• Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Co2/Inert gas flooding system found provided	MR	

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. The shortcomings communicated vide even letter dated 19/01/2018 have been complied. ✓

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

R.N. Singh
01/3/18

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO (BCP)

CIC, HQ Building, Old JNU Campus, Baba Gang Nath Marg, Munirka, New Delhi-110067

DO (SD)

R.N. Singh
11/3/18

R.N. Singh

R.N. Singh
1/3

R.N. Singh

m.scell

FT/10.

R.N. Singh
1/3.

R.N. Singh
F.T. is put up for his please.

R.N. Singh

R.N. Singh
01/3/18

R.N. Singh

m.scell *R.N. Singh*
01/3

R.N. Singh
01/3/18