

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/Ind./SZ/2018/351

Dated: 06/03/2018

FIRE SAFETY CERTIFICATE

Certified that the **Alankrit Handicrafts Pvt. Ltd.** situated at **208, Okhla Industrial Estate, Phase-III, New Delhi-110020**, comprised of two tier Basement, Ground and two Upper floors was granted FSC by this department vide letter No. F6/DFS/MS/2010/2008 dated 07/07/2010. The premises was re-inspected by the officer concerned of this department on 20/02/2018 in the presence of Ms. Sonam (Jr. Admin. Executive) and found that the said Commercial Building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Industrial occupancy (Group-G)**" with effect from 06/03/2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....06/03/2018.....at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Tel: 011-23412225

Copy to:-

1. The Executive Engineer (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024.
2. The Authorized signatory, Alankrit Handicrafts Pvt. Ltd., Okhla Industrial Estate, Phase-III, New Delhi-110020

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year in Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Alankrit Handicrafts Pvt. Ltd., 208, Okhla Industrial Estate, Phase-III, New Delhi-110020.
2. Type of Occupancy : Industrial "Group-G"
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/2010/2008 dated 07/07/2010
5. Fire Safety directives letter No : F6/DFS/MS/BP/2007/1965 dated 23/07/2007
6. Date of inspection : 20/02/2018
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation of officer from the building side : Ms. Sonam (Jr. Admin. Executive)
9. Year of Construction : 2010 **[Basement + Ground + 2 Upper Floors]**
10. Applicant's letter No. : Form-J, outdoor diary no. 1661 dated 01/02/2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	9m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Provided	MR
	• Basements	Two	Provided	MR
	b. Width of staircases			
	• Upper Floor	1.25m	1.37m & 1.33m	MR
	• Basements	1.25m	1.68m & 1.33m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Two	Two	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	Provided (final exit)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30ACPH	Exhaust Fan Provided	MR
	• Upper floors	12ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	22 No's	Provided	MR
	• Types	ABC/W.CO2/CO2	8/8/6	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	1 No's	1 No's	MR
	• Length of hose reel hose	36m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Found removed at some places	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Location of alarm	All Area	Provided	MR

8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground & Above Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	1 No's	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	1 No's	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	6 No's	5 No's	MR (old Case)
	<ul style="list-style-type: none"> Hose Box 	6 No's	5 No's	MR (old Case)
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	2280 LPM	Provided	MR
		55m	Provided	MR
		One	Provided	MR
		180 LPM	Provided	MR
		55m	Provided	MR
		2280 LPM	Provided	MR
		55m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000 Lts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Lts	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
-----	---	----	----	----

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. The shortcomings communicated vide letter no. F6/DFS/MS/Ind.SZ/2017/3035 dated 16/11/2017 found complied. Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA of Form "H" is put up for approval.

A. K. Malik
20/2/18

Signature of Inspecting Officer
Name: A. K. Malik
Designation: Divisional Officer

DY. CFO(SZ)

2/2



CF(S)

Point no. 12 can be given as short coming as no where in the note on N/3 + N/4 no of yard hydrant is mentioned then why it is taken as old case M/R.

DCFSZ

2/2

Provision of yard hydrant is mentioned at N/4. w.r.t. quantity no. of is not mentioned for other points too.
be submitted for a fair advise M.

2/2



*16511 of 052
12/6/3.*