

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2018/394

Dated: 12 /03/2018

FIRE SAFETY CERTIFICATE

Certified that the **KIIT World School, (New -state Academy Sr. Secondary School)** located at **Zone H-4, Pitam Pura, Delhi – 110034** Comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/WZ/2015/1265 Dated 16-07-2015. The premises was re inspected by the officer concerned of this department on 20-02-2018 in the presence of Sh. Smt Sanjeeta Bhatiya (Principal) and observed that a new block is under construction in the school premises & is not ready for inspection. All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262 – 362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 12/03/2018 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/03/2018..... at New Delhi by.

(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal,
KIIT World School
Zone H-4, Pitam Pura, Delhi – 110034

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Pota cabins on terrace shall not be used for school activities.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: KIIT world school, Zone H-4, Pitampura, Delhi-110034
2. Type of Occupancy : Educational (Ground + 3 Upper Floor & **Pota cabins at the terrace being used for storage**) Except new Block of Ground floor only.
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2015/1265 Dated 16-07-2015
5. Fire Safety directives Letter No. : DOE circular 262-362 Dated 17/01/2005
6. Date of inspection : 21/02/2018
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Smt Sangitta Bhatia (Principal)
9. Year of Construction : 1992
10. Applicant's letter No. : KIIT/18/16116, Dated 22/01/2018

No. of Students=1432
 No. of class rooms=31
 Plot area=5562m²
 Covered area=2781 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. 262-362 Dated 17/01/2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	370cm Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors			
	• Basements	1.5m	2x152cm & 1x132cm (include railing)	MR Old case
	c. Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization			
	d. No of continuous staircase to terrace	NA	NA	NA
		NA	NA	NA
	e. Width Of Corridor	1	Provided	MR
	f. Door Size	NA	236cm Provided	NA
		1 mtrs	1m Provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	20 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	02	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	02	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump 	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm& 180 Lpm	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity 	20000 ltrs	provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltr	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/WZ/2015/1265 D dated 16-07-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Handwritten signature]
22/7/18

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name *Uday Vir Singh*
Designation *ADCP*

Name
Designation

[Handwritten signature]
[Handwritten signature]
[Handwritten signature]
Cfo - West
3/3/18
FDPIS

[Handwritten signature]
ADP/W

Sir PT letter is put up for

sign. p/c

[Handwritten signature]
7/3/18