

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

NO. F.6/DFS/MS/NDZ/2018/ 350

Dated:- 05/03/2018

FIRE SAFETY CERTIFICATE

Certified that the M/S (NCAER), National council of Applied Economic Research at Parisila Bhawan, 11 I.P Estate, New Delhi 110002. Comprised of 2Basement +Ground + 1 Conference Block+ 08 upper floors. and occupied by M/S (NCAER), Parisila Bhawan, 11, I.P Estate, New Delhi 110002. have complied with the fire prevention & fire safety requirements in accordance. with rule 33 of the Delhi Fire Service rules 2010 and verified by the officer concerned of Delhi Fire Service on 28/02/2018 in the presence of Sh. Anil Kumar Sharma (Senior Secretary) and the building / premises, is fit for occupancy class of Business Building Group E with effect from 05/03/18 for period of three years in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 05/03/18 at New Delhi.



(SUNIL CHAWDHARY)
Dy. Chief Fire Officer
Delhi Fire Service

- Copy to:- 1.The Medical Officer of Health,
NDMC Palika Kendra New Delhi.
2. Sh. Shekhar shah (Director Genral)
National Council of Applied Economic Research
Parisila Bhawan, 11, I.P Estate, New Delhi 110001.

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

INSPECTION REPORT

1. Name & address of the building : **National Council of Applied Economic Research** at Parisila Bhawan, 11 Indraprastha Estate, New Delhi 110002.
2. Building is comprised of : 2,Basement + G +8 Upper Floor
3. Type of Occupancy : Business Building
4. Type of Case : New case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F6/DFS/MS/BP/2016/1074 Dated 28/04/16
7. Date of Inspection : 28/02/2018
8. Name of the Inspecting Officers: : Vipin kental (C.F.O) NDZ , Sunil Chawdhary (Dy.CFO) NDZ
9. Name of the designation of Officer from the building side : Mr. Anil Kumar Sharma
10. Year of Construction : Old
11. Applicant's letter No : Nil

S.No	Minimum standards on fire prevention and fire safety U/R33	BBL / NBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 m	Provided	MR
	Gate width	06 m	Provided	MR
	Width of internal road	06 m	Provided	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2Nos.	Provided	MR
	Basement	2 No.	Provided	MR
	B. Width of Staircases			
	Upper Floor	1.5 mtr	Provided	MR
	Basement	1.5 mtr	Provided	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	Required	Provided	MR
	g. Width of Corridor	2 mtr	Provided	MR
h. Door Size	1.5 mtr	Provided	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	Required	Provided	MR
	Water curtain	Required	Provided	N.A.
	Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fan	MR
	Upper floor	12a/c per hour	Exhaust fan	MR

5.	Fire Extinguisher			
	Total numbers	100 no.	Provided	MR
	types	CO ₂ & ABC	Provided	MR
	IS marking	ISI marked	Provided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	Required	Provided	MR
	Length of hose reel hose	Required	Provided	MR
	Nozzle diameter	Required	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Required	Provided	MR
	Location of main panel	Required	Provided	MR
	Location of repeater panel	Required	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	Required	Provided	MR
	Number of hydrants per floor	Required	Provided	MR
	Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	Required	Provided	MR
	Hose Box	Required	Provided	MR
13	Pumping Arrangements.			
	Ground Level			
	Discharge of main Pump	2280 lpm	Provided	MR
	Head of Main Pump	80 m	Provided	MR
	Number of main pumps	2 no	Provided	MR
	Jockey pump out put	220 no ^{2 PM}	Provided	MR
	Jockey pump head	80 m	Provided	MR
	Standby pump out put	2280 3900 lpm	Provided	MR
	Standby pump Head	Required	Provided	MR
	Auto Starting /Manual stopping	Required	Provided	MR
	Pump House Access	Required	Provided	MR
	Terrace Level			
	Discharge of pump	N.A.	N.A.	N.A.
	Head of the Pump	N.A.	N.A.	N.A.
	Power supply	N.A.	N.A.	N.A.
	Auto Starting of pump	N.A.	N.A.	N.A.

14	Captive Water Storage for Fire Fighting			
	Underground tank capacity	229/11 200 kv.	Provided	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	20,000 ltr	80,000 Liter	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	Required	Provided	MR
	Pressurization of Lift lobby	Required	Provided	MR
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	Required	Provided	MR
	Location	6 th floor	Provided	MR
19	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	Required	Provided	MR
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Provided	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping In view of the Substantial compliance of the compliance of the minimum standards on fire prevention and fire safety measures as required under the Rule it is recommended to grant fire safety Certificate under rule 35 of the Delhi Fire Service Rule 2010 recommended for FSC please.

bestest
Signature of the Inspecting Officer

Name :- Vipin Kental

Designation :- C.F.O(NDZ)

Signature of the Inspecting Officer

Name :- Sunil Chawdhary

Designation:- DY. CFO(NDZ)

F.I. Letter is put up for signature
p. beards

Miscell

4/2/CF & NDZ
5/3