

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/EH/2018/SZ/ 388

Dated: 8/3/18

**FIRE SAFETY CERTIFICATE**

Certified that the Restaurant in the name & style of M/s **Haldiram Marketing Pvt. Ltd.**, located at Shop No-31, Ground floor & Shop No-103, First floor, Multilevel Car Parking cum Commercial Complex, DLF South Squire Mall, Sarojini Nagar, New Delhi-110023, comprised of **Basement, Ground plus Eight upper floors**. The restaurant premise was inspected by the officer concerned of this department on 23/02/2018 in presence of Mr. Nandan (Manager) and found that the said restaurant premise have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly**" Group-D (Restaurant) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 8/3/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

  
01

Copy to: -

1. The Manager (Admn & Liaison), M/s Haldiram Marketing Pvt, B-1/H-3, Mohan Co-operative Industrial Estate, Main Mathura Road, new Delhi-110 044
2. The Medical Officer of Health, N.D.M.C, Palika Kendra, New Delhi-110 001

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	M/s Haldiram Marketing Pvt. Ltd, Shop No-31, Ground Floor and Shop No-103, First Floor, Multilevel Car Parking cum Commercial Complex, DLF South Square Mall, Sarojini Nagar, New Delhi-110 023		
2	Type of Occupancy	Assembly, Group-D (Restaurant)		
3	Building comprised of	Basement, Ground plus Eight upper floors.		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2008/3507 Dated 22-12-2008 and F.6/DFS/MSBP/2014/17 Dated 17/01/2014		
7	Date of Inspection	23-02-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Nandan (Manager)		
10	Year of construction	2011	Restt running at ground & 1 <sup>st</sup> floor of the bldg	
11	Applicant letter No.	Nil dated 07-02-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>	FSC No.F.6/DFS/MS/Parking/2015/SZ/1509 Dt. 18/08/2015		
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Restt. within Multilevel Car Parking	9 mtr 4.5 mtr 6 mtr from two sides	MR MR MR
2	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a. Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	Required N/A	03 + 01 No's (01 No from inside of the Restt N/A	MR N/A
	<b>b. Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	1.50m N/A	1.5m each N/A	MR N/A
	<b>c. Protection of exits</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Required Required	Provided Provided	MR MR
	<b>d. No. of continuous staircase to terrace</b>	Required	Three	MR
	<b>e. Width of corridor</b>	1.5 / 2m	Provided	MR
	<b>f. Door size</b>	1.5m & 2m	1.5m & 2m	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	Required Required Required N/A Required	Provided Provided 2 Hrs N/A Provided	MR MR MR N/A MR
4.	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	N/A Exhaust fan provided	N/A MR
5.	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	6 No's ABC / Co2 ISI marked	10 No's ABC type Provided	MR MR MR
6.	<b>First Aid Hose Reels.</b>	Fire fighting system is common for entire complex		
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	2 No's 30 m 5 mm	02 No's 30 m 5 mm	MR MR MR

7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	Required	Smoke & Heat type	MR
	• Location of Main Panel	Required	Ground floor	MR
	• Location of Repeater Panel	Control Room	Control Room	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Each floor	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>	Fire fighting system is common for entire complex		
	• Basement	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	<b>Internal Hydrants.</b>	Fire fighting system is common for entire complex		
	• Size of Riser/Down-comer	Required	150 mm	MR
	• Number of Hydrant per floor	Required	02 No's	MR
	• Hose box.	Required	02 No's	MR
12.	<b>Yard Hydrants.</b>	Fire fighting system is common for entire complex		
	• Total number of hydrants.	Required	04 No's	MR
	• Hose box.	Required	04 No's	MR
13.	<b>Pumping arrangements.</b>	Fire fighting system is common for entire complex		
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	2850 LPM x 2	2850 LPM x 2	MR
	➤ Head of main pump.	60 mtr	60 mtr	MR
	➤ Number of main pumps.	02 No's	02 No's	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	60 mtr	60 mtr	MR
	➤ Standby Pump output.	2850 LPM	2850 LPM	MR
	➤ Standby Pump head.	60 mtr	60 mtr	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>	Fire fighting system is common for entire complex		
	• Underground tank capacity.	1,50,000 ltrs	1,50,000 ltrs	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	25,000 ltrs	25,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	Required	Provided	MR
	• Pressurization of lift lobby.	Required	Provided	MR
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	Not required		
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	<b>Fire Control Room.</b>	Fire fighting system is common for entire complex			
		• Detector System Panel.	N/A	Provided	N/A
		• Flow Switch Panel.	N/A	N/A	N/A
		• PA system Panel.	N/A	N/A	N/A
		• Battery backup	N/A	Provided	N/A
	• Building floor plan	N/A	N/A	N/A	
20.	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	Required	Provided CO2 flooding system for LT & HT panel	MR	

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. The shortcomings communicated vide even letter dated 17/06/2016 found complied. ✓

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

*R.N. Singh*  
22/12

Signature of the Inspecting Officer  
Name : R.N. Singh  
Designation: ADO (BCP)

M/s Haldiram Marketing Pvt Ltd at Shop No-31 (GF) & 103 (FF), MLCPCCC, Sarojini Nagar, New Delhi

DO (SD)

*Prakash*  
28/12/18

*ep/s2*

*deap*  
28/12



1662/CF-52  
6/12/18

CFO epn

m.s cell FT 101.

*Ue*  
8/3.

FT letter is put up for sign. ple.

*ep/s2*

*Ue*  
8/3.

*R.N. Singh*  
6/13