

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001



No. F.6/DFS/MS/BQ/2018/NDZ/ 378

Dated: 8/3/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Golden Knot Banquet Hall (Previously known as Golden Leaf Banquet Hall) running at ground & mezzanine floor of building comprised of basement, ground, mezzanine & first floors at B-15 (Old No. 91/386/12) Main Road, Gazipur, Delhi, owned/occupied by M/s Golden Knot Banquet Hall was granted fire safety certificate vide letter no. F6/DFS/MS/GH/2015/NDZ/591 Dated 22/04/15. The Assembly building was inspected by officer concerned of this department on 27/02/18 in the presence of Sh. Sunil Kumar Singh (Owner) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rule 2010 and found that the GF+Mezzanine floor of building is fit for occupancy Group D "Assembly Building" with effect from ... 8/3/18 for a period of **three** years, subject to conditions printed overleaf.

Issued on 8/3/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer


To

Sh. Sunil Kumar Singh (Owner)
M/s Golden Knot Banquet Hall,
B-15 (OLD NO.91/386/12) Main Road, Gazipur, Delhi

Copy to:-

The Dy. Health Officer,
EDMC, Health department,
Shahdara (South) Zone, Karkardooma,
Shahdara, Delhi. Delhi-51

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub-rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This NOC may not be treated in any case for regularizations of unauthorized construction or unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Golden Knot Banquet Hall, at B-15 (OLD NO.91/386/12)
Main Road , Gazipur, Delhi.
2. Building is comprised of : B+G+Mazzanine+First (Banquet Hall running at Gr+Mazzanine)
3. Type of Occupancy : Assembly Building(Banquet Hall)
4. Type of Case : **Renewal**
5. Details of Previous NOC : F6/DFS/MS/GH/2015/NDZ/591 Dated 22/04/15
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 27/02/18
8. Name of the Inspecting Officers: : ADO R.K.Yadav
9. Name of the designation of Officer
from the building side : Sh.Sunil Kumar Singh(Owner)
10. Year of Construction : 2000
11. Applicant's letter No : dated 30/01/18

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement/NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	15 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 no.	2 nos.	MR
	Basement	2 nos.	2 nos.+ 1 Ramp	MR
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5 M & .90 m	MR
	Basement	1.5 m	1.5 M & .90 m +3 ramp	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	1 no.	2 nos.	MR
	g. Width of Corridor	N.A	N.A	N.A
	h. Door Size	2 m	4 m & 1.5 m	MR
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	Required	Ventilated	MR
	Upper floor	Required	Ventilated	MR

5.	Fire Extinguisher			
	Total numbers	10 nos.	12 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	Provided	MR
	Location of main panel	Main Gate	Provided	MR
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters's location	Staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	01 no.	01 no.	MR
	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump			
	➤ Head of the Pump	900 LPM	900 LPM	MR
	➤ Power supply	40 m	Not Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR

N/7

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	15,000 Liters	25,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	N.A	N.A	N.A
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

Previously the Golden Leaf Banquet Hall running at the same address. FSC issued vide letter no. F6/DFS/MS/GH/2015/NDZ/591 Dated 22/04/15 and now owner has changed the name of the Banquet hall i.e. Golden Knot.

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the NBC Part-IV it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav
27/2/2018

Signature of the Inspecting Officer

Name : R.K.Yadav

Designation : ADO (LN)

DO(ED)

Submitted for approval please.

*391/CF/NDZ
6/3/18/2*

DY(FO)NDZ

[Signature]

[Signature]
27/2/18