

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/Indl./2018/SZ/ 383

Dated: ..9/3/18

FIRE SAFETY CERTIFICATE

Certified that M/s **Galaxy Toyota** (A Unit of Galaxy Automobiles Pvt. Ltd.) located at Plot No. 84, Okhla Industrial Area, Phase-I, New Delhi, Comprised of **Basement, Ground + 02 upper floors**, Owned/Occupied by M/s Galaxy Automobiles Pvt. Limited. The premises was inspected by the officer concerned of this department on 26/02/2018 in presence of Mr. Gaurav (Engineer) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Industrial Building** Group-G as above with effect from 9.1.3/... 2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 9/3/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. M/s Galaxy Toyota at Plot No. 84, Okhla Indl. Area, Phase-I, New Delhi-110020
2. The Ex. Engineer (Bldg.), HQ-I, SDMC, 8th Floor, Civic Centre, Minto Road, N. Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	M/s GALAXY TOYOTA, PLOT NO. 84, OKHLA INDUSTRIAL AREA, PHASE-1, NEW DELHI (A UNIT OF GALAXY AUTOMOBILES PVT. LTD)		
2	Type of Occupancy	Industrial Building (Group-G)		
3	Building Comprised of	Basement, Ground plus two upper floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No.	F.6/DFS/MS/BP/2015/118 Dated 30-04-2015		
7	Date of Inspection	26-02-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Gaurav (Engineer)		
10	Year of construction			
11	Applicant letter No.	Nil dated 27/01/2018, ODD No. 1865 Dt. 06-02-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL & Directives requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 mtr	18 mtr	MR
	• Gate width	5.5 mtr	5.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	3 No's	3 No's	MR
	• Basement floor	4 No's	4 No's	MR
	b. Width of Staircase			
	• Upper floors	1.50 mtr	1.50m each	MR
	• Basement floor	1.50 mtr	1.50m x 3 & 1.90m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	Three	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	One / 300m ²	30 No's	MR
	• Types	ABC / Co2	ABC-20, Co2-10	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

M/s Galaxy Toyota, Plot No. 84, Okhla Industrial Area, Phase-I, New Delhi


7	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	Provided at GF	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	All Area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	150 mm	Provided	MR
	• Number of Hydrant per floor	1 No	Provided	MR
	• Hose box.	1 No	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	4 No's	Provided	MR
	• Hose box.	4 No's	Provided	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump	2280 LPM	2280 LPM	MR
	➤ Head of main pump.	60 mtr	60 mtr	MR
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	60 mtr	60 mtr	MR
	➤ Standby Pump output.	2280 LPM	2280 LPM	MR
	➤ Standby Pump head.	60 mtr	60 mtr	MR
	➤ Auto Starting/Manual stopping.	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	1,00,000 ltrs	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	Water curtain	Provided	MR
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area		Not required	
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19.	Fire Control Room.	Not required		
	• Detector System Panel.	NA	NA	NA
	• Flow Switch Panel.	NA	NA	NA
	• PA system Panel.	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Co2 type fire extinguisher provided near electrical panel	MR

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. The system checked on DG Set due to non availability of electricity.

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for perusal and signature please


 Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO (BCP)

M/s Galaxy Toyota, Plot No. 84, Okhla Industrial Area, Phase-I, New Delhi

DO (SD)

Amal
28/1/18

dy. CFO (S)

1660/CFAR
6/2/9/13

deep
1/3



CFOS *m-sell* *FT B.*
W
5/3

FT letter is put up for signature.
CFOS *m'sell* *W*
6/3