

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School//NDZ/2018/445

Dated: 19.03.18

FIRE SAFETY CERTIFICATE

Certified that the M/S M.S. Education & Welfare Trust, Kh. No. 14 & 15, Village Biharipur, Sonia vihar, Delhi – 94, comprised of basement, ground plus three upper floors, owned / occupied by M.S. Education & Welfare Trust was inspected by the officer concerned of this department on 20/02/18 in presence of Aman Ullah Khan, owner of the school and found that the school building is fit for occupancy class 'B 'Educational Building' for with effect from ...19.03.18... for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....19.03.18.....at New Delhi by

u
16/3

(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

o/c h

To,
The Principal
M.S. Education & Welfare Trust,
Kh. No. 14&15, Village Biharipur, Sonia vihar,
Delhi – 94.

Copy to:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

ADo / SHAH

- 2/11
1. Name & address of the building : M.S. Education & Welfare Trust, Kh. No. 14&15, Village Biharipur, Sonia vihar, Delhi – 94.
 2. Building is comprised of : B + G + 3 upper floors
 3. Type of Occupancy : Educational
 4. Type of Case : **New**
 5. Details of Previous FSC letter :
 6. Fire Safety circular No : NBC Part IV
 7. Date of Inspection : 20/02/18
 8. Name of the Inspecting officers : ADO Om Prakash
 9. Name and designation of Officer from the building side : Aman Ullah Khan (owner)
 10. Year of Construction : 2013
 11. Applicant's letter No : Nil Dated: 05/02/2018.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement NBC - IV	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	10 Mtrs	MR
	• Gate width	4.5 m	5.0 m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 no.	02 no.	MR
	• Basement	02 no.	02 no.	MR
	B. Width of Staircases			
	• Upper Floor	1.5 m	1.5 m each	MR
	• Basement	1.5 m	1.5 m each	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 nos.	02 nos.	MR
	g. Width of Corridor	1.5 m	2.38 m	MR
	h. Door Size	1.0 m	1.5 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	24 nos.	30 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Require	Provided	MR
9	Public address System.	Require	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Require	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose Box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000Liters	15,000Liters	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

It is recommended to Issue Fire Safety Certificate.

Ombakar 27/2/20

Signature of the Inspecting Officer
Name: Om Prakash
Designation : ADO

Submitted for approval please

DO (East)

for ref
27/2/18

DCFO/NDZ

[Signature]
28/2

CEG

m.scell

F.T.M.

1/3

F.T. Lella is Prepared and put up for signatrs plan.

Do Cfd Hcy

m.scell *1/3*

[Signature]
3/3

389/CF/N/2
1/3.