

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2018 / w2 / 436

Dated: 16 / 3 / 2018

**FIRE SAFETY CERTIFICATE**

Certified that the Mount Abu Public School located at Sector-5, Pkt.-B-8, Rohini, Delhi-85 comprised of **Ground + 03 upper floors and Structure/Porta cabin on the terrace of third floor** (School is running on Ground & 03 upper floors) owned/ occupied by Mount Abu Public School was granted NOC by this department vide letter No **F6/DFS/MS/School/2013/WZ/1061 dated 10/10/2013**. The premise was re-inspected by the officer concerned of this department on 23.02.2018 in the presence of **Mrs. Jyoti Arora, Principal** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B" for Ground & 03 upper floors only** with effect from 16/3/18..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. The School management has given undertaking that the structure at above 3<sup>rd</sup> floor will not be use for activities.

Issued on 16/3/18..... at New Delhi

  
(Atul Garg)  
Chief Fire Officer  
Ph: 011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, Mount Abu Public School, Sector-5, Pkt.-B-8, Rohini, Delhi-110085.

**INSPECTION REPORT**

- 1 Name & address of the building : Mount Abu Public School, Sector-5, Pkt.-B-8, Rohini, Delhi-85. .
- 2 Type of Occupancy :Educational
- 3 Type of Case :Renewal (G+03 upper floorss)
- 4 Details of previous NOC :F6/DFS/MS/School/2013/WZ/1061 dated 10/10/2013
- 5 Fire Safety directives letter No : NBC Part-4.
- 6 Date of inspection : 23.02.2018
- 7 Name of the Inspecting Officers : ADO (RN)
- 8 Name and designation of officers  
from the building side : Mrs Jyoti Arora (Principal)
9. Year of Construction : --
10. Applicant's letter No. :MAPS/17-18/6194 Dated 01.02.2018

Plot Area-.800 sq m

Covered Area:400 sq.m,

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	<b>b. Width of staircases</b>			
	• Upper Floors	1.50m	1.50 m each	MR
	• Basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	01m	01m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA



	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	NA	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	23 nos	25nos	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC/CO2	ABC—25	MR
	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	Provided	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	02	02	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	02	02	MR

13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900 lpm	900lpm	MR
		40m	40m	MR
		Required	Provided	MR
Required	Provided	MR		
14	<b>Captive Water Storage for fire fighting.</b>			
<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	10000 ltrs	10000 ltrs	MR	
	Required	Provided	MR	
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
17	<b>Standby power supply</b>			
Required	Provided	MR		
18	<b>Refuge Area.</b>			
<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A	
	N/A	N/A	N/A	
19	<b>Fire Control Room</b>			

	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, the FSC issued vide letter of even no 1061 dated 10.10.2013 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

*Dy C/S/W 2*  
*[Signature]*

*[Signature]*  
 12/8/18

*[Signature]*  
 Signature of the Inspecting Officer  
 Name: - Rajesh Kumar  
 Designation: - ADO/RN