

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 444

Dated: 19.03.18

FIRE SAFETY CERTIFICATE

Certified that the M/s Nav Jeevan Convent School, C-199, Gali No.-7, Bhajanpura, Delhi - 110053. comprised of Ground plus two upper floors. The School is running on ground plus one upper floor only. Owned / occupied by Nav Jeevan Convent School was issued FSC vide letter No. F6/DFS/MS/2006/2994 Dated: 09/10/2006. The school building was re-inspected by the officer concerned of this department on 06/02/18 in presence of owner of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. 262-362 dated 17/01/05 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 19.03.18.....for a period three year, subject to conditions printed overleaf.

Issued on.....19.03.18.....at New Delhi by

uc
16/3

(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

alc
hr

To,
The Principal,
Nav Jeevan Convent School,
C-199, Gali No.-7, Bhajanpura,
Delhi - 110053.

Copy to:-
The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi-54.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Nav Jeevan Convent School,C-199 Gali -7,
Bhajanpura Delhi- 110053 Delhi - 53.
2. Building is comprised of : G+2 (Running on G+1 only)
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC letter : F.6/DFS/MS/2206/2994 dated 9/10/06.
6. Fire Safety circular No : 262-362 Dated: 17/01/15 Issued by Direct of Education
7. Date of Inspection : 6/02/18
8. Name of the Inspecting officers : ADO Om prakash
9. Name and designation of Officer
10. From the building side : Sh. Mohit Bansal (owner)
11. Year of Construction : 2004
12. Applicant's letter No : Nil dated 16.1.2018.

NO.	Minimum Standards on fire prevention and fire safety U/R-33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	10 Mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 no.	01 no.	MR old case
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 m	1.5 m,	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01 no.	MR
	g. Width of Corridor	1. m	1 m	MR
	h. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06Nos.	06 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01	01	MR
	• Length of hose reel hose	30M	30M	MR
	• Nozzle diameter	05mm	05mm	MR
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	M/R
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100m	100m	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	225 LPM	225 LPM	MR
	➤ Head of the Pump	40 m	40M	MR
	➤ Power supply	Required	provided	MR
	➤ Auto Starting of pump	Required	provided	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500Liters	2500Liters	MR
15	Exit Signage.	Required.	provided.	M/R

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	provided	MR
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules. The Fire safety Certificate issued vide letter no.F.6/DFS/MS/2006/2994 dated 09.10.06 renewal under rule 37 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Om Prakash
23/2/18

Name: Om prakash

Designation : ADO(Shahdara)

Submitted for approval please.

DO (ED)

DUCB/NDY
[Signature]

[Signature]
24/2/18

CRP mscell *16/1/13*

Ft. lalli is prepared and put up for signals pho

388/CF/NM2
11.5.16/2