

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2018/ 471

Dated: 21 / 03 / 2018

**FIRE SAFETY CERTIFICATE**

Certified that the DAV Centenary Public School (School ID-1310280) at Sector-B / 4, Pocket-5 DDA Project, Narela, Delhi-110040, comprised of Ground + Three Upper Floors owned / occupied by D.A.V. Centenary Public School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/ND2/2015/58 dated 12/01/15. The premises was re-inspected by the officer concerned of Fire Service on 24.02.2018 in the presence of Mr. Bimlesh Jha (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy class Educational (Group-B) with effect from 21 / 03 / 2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 21/03/18 at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER.



Copy to :-

1. Mr. Bimlesh Jha (Principal), DAV Centenary Public School (School ID-1310280) at Sector-B / 4, Pocket-5 DDA Project, Narela, Delhi-110040.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.

1. Name & address of the building: DAV Centenary Public School, B-4, Pocket-5, DDA Project, Narela, Delhi-110040.
2. Type of Occupancy : Educational (G+3)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/ND2/2015/58 dated 12/01/15
5. Fire Safety directives Letter No. : DOE Circular Dated 17/01/2005
6. Date of inspection : 24/02/2018
7. Name of the Inspecting Officer : A.D.O. (Jwala Puri)
8. Name and designation of Officer from the building side : Mr. Bimlesh Jha (Principal)
9. Year of Construction : 1995-96
10. Applicant's letter No. : DAVCPS/1185/2017 dated 12/01/2018

Total Area – 15,996 Yard <sup>2</sup> Covered Area – 6467.14 Yard <sup>2</sup>
---

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dt. 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	13.5 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02+01 ramp	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 Mtr. (Old case)	1.35mtr x 2 & 1 Ramp of 1.48 mtr	MR (Old Case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.00 Mtr.	1.10 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	32	32	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR
	• IS marking	Required	Provided	M/R



N/12

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	NR
9.	Public Address System	Required	Provided	NR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	4"	4"	MR
	• Number of hydrants per floor	2	2 at each floor	MR
	• Hose Box	2	2 at each floor	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	1	N/A
	• Hose Box	N/A	1	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of capacity			



	power		N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	NR
9.	Public Address System	Required	Provided	NR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	4"	4"	MR
	• Number of hydrants per floor	2	2 at each floor	MR
	• Hose Box	2	2 at each floor	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	1	N/A
	• Hose Box	N/A	1	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 Ltr	5000 Ltr x 4	MR

N/13

		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	Provided	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-A) General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape route .....:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring .....:- Conduit Wiring MCB and ELCB.....  
Electric circuit .....:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set ..... :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/ND2/2015/58 dated 12/01/15 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O/CS,

*[Signature]* 5/3/28

*[Signature]*

*[Signature]*  
28/2/18

Signature of the Inspecting Officer  
Name : A.K. Jaiswal  
Designation : A.D.O. (Jwala Puri)

28/2/18