

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 483

Dated: 23/3/18.

FIRE SAFETY CERTIFICATE

Certified that **New Hostel Block of Delhi Public School** located at Sector-XII, R.K. Puram, New Delhi-110022, comprises of **basement, ground and four upper floors** owned/occupied by Delhi Public School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/1235 dated 22/09/2014. The premises was re-inspected by officer concerned of this department on 05/03/2018 in presence of Mr. AS Bhati (Admin) and found that the said hostel building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential** (Hostel) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/3/18. at New Delhi by

W
22/3
(Vipin Kental)
Chief Fire Officer
Pir
01

Copy to: -

1. Ms. Vanita Sehgal (Principal), Delhi Public School, Sec-XII, RK Puram, New Delhi-110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."


INSPECTION REPORT

| | | | | |
|---------------|--|---|------------------------------|-----------------------|
| 1 | Name & Address of the Building | NEW HOSTEL BLOCK, DELHI PUBLIC SCHOOL, SECTOR-XII, R.K. PURAM, NEW DELHI-110022 | | |
| 2 | Type of Occupancy | Residential Building (Hostel) | | |
| 3 | Building Comprised of | Basement, Ground + 4 upper floors | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F.6/DFS/MS/School/2014/SZ/1235 Dt. 22/09/2014 | | |
| 6 | Fire Safety Directives Letter No | F.6/DFS/MS/BP/97/1957 Dated 17-12-1997 | | |
| 7 | Date of Inspection | 05-03-2018 | | |
| 8 | Name of the Inspecting Officers | R.N. Singh, ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mr. AS Bhati (Admin) | | |
| 10 | Year of construction | 1996-2002 | | |
| 11 | Applicant letter No. | DPSR/DFS/FF/NOC/10-17 Dated 13/10/2017 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC requirement | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | 9 mtr | Provided | MR |
| | • Gate width | 4.5 mtr | Provided | MR |
| | • Width of internal road | 6 mtr | Provided | MR |
| 2 | Number, width, type & arrangement of exits | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors | 2 No's | 3 No's | MR |
| | ➤ Basement floor | 2 No's | 3 No's | MR |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.25 mtr | 1.20, 1.02 & 1.02 mtr | MR |
| | ➤ Basement floor | 1.25 mtr | 1.02, 1.02 & 01 exit of 1.5m | MR |
| | c) Protection of exits | | | |
| | ➤ Fire check door | N/A | N/A | N/A |
| | ➤ Pressurization | N/A | N/A | N/A |
| | d) No. of continuous staircase to terrace | One | One | MR |
| | e) Width of corridor | N/A | N/A | N/A |
| | f) Door size | N/A | N/A | N/A |
| 3 | Compartmentation. | | | |
| | • Fire check door. | N/A | N/A | N/A |
| | • Sealing of electrical shafts. | N/A | N/A | N/A |
| | • Fire rating of shaft door. | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire dampers. | N/A | N/A | N/A |
| 4. | Smoke Management system. | | | |
| | • Basement | 30 ACPH | Exhaust fans provided | MR |
| | • Upper floors | 12 ACPH | N/A | N/A |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | | 40 No's | MR |
| | • Types | ISI marked | ABC & Co2 | MR |
| | • ISI Marking | | Provided | MR |
| 6. | First Aid Hose-reels. | | | |
| | • Total numbers on each floor. | 01 | One | MR |
| | • Length of hose-reel hose. | Hose-reel | 30 m | MR |
| | • Nozzle Diameter | | 5 mm | MR |

New Hostel Block, Delhi Public School, Sector-XII, R.K. Puram, New Delhi-110022


| | | | | |
|-----|---|------------------|------------------|-----|
| 7 | Automatic fire detection & alarming system | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | Required | Provided | MR |
| | • Upper floors | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants. | | | |
| | • Size of Riser/Down-comer | 100 mm | Provided | MR |
| | • Number of Hydrant per floor | One | Provided | MR |
| | • Hose box. | One | Provided | MR |
| 12. | Yard Hydrants. | | | |
| | • Total number of hydrants. | N/A | N/A | N/A |
| | • Hose box. | N/A | N/A | N/A |
| 13. | Pumping arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main pump. | N/A | N/A | N/A |
| | ➤ Head of main pump. | N/A | N/A | N/A |
| | ➤ Number of main pumps. | N/A | N/A | N/A |
| | ➤ Jockey Pump output. | N/A | N/A | N/A |
| | ➤ Jockey Pump head. | N/A | N/A | N/A |
| | ➤ Standby Pump output. | N/A | N/A | N/A |
| | ➤ Standby pump head. | N/A | N/A | N/A |
| | ➤ Auto Starting/Manual Stopping. | N/A | N/A | N/A |
| | • Terrace Level | | | |
| | ➤ Discharge of pump. | 450 LPM (2 No's) | 1320 & 450 LPM | MR |
| | ➤ Head of pump. | 40 mtr | 40 mtr each | MR |
| | ➤ Power supply. | Required | Provided | MR |
| | ➤ Auto starting of pump. | Required | Not on auto mode | NMR |
| 14. | Captive water storage for Fire Fighting. | | | |
| | • Underground tank capacity. | N/A | 1,00,000 Ltr | N/A |
| | ➤ Draw-off connection. | N/A | Provided | N/A |
| | ➤ Fire Service Inlet. | N/A | Provided | N/A |
| | ➤ Access to tank. | N/A | Provided | N/A |
| | • Overhead tank capacity. | 30,000 ltrs | Provided | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provisions of Lifts. | | | |
| | • Pressurization of lift shaft. | N/A | N/A | N/A |
| | • Pressurization of lift lobby. | N/A | N/A | N/A |
| | • Communication in lift car. | N/A | N/A | N/A |
| | • Fireman's switch. | N/A | N/A | N/A |
| | • Lift signage. | N/A | N/A | N/A |
| 17 | Standby Power Supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |

New Hostel Block, Delhi Public School, Sector-XII, R.K. Puram, New Delhi-110022

| | | | | |
|---|---|-----|-----|-----|
| 19. | Fire Control Room. | | | |
| | • Detector System Panel. | N/A | N/A | N/A |
| | • Flow Switch Panel. | N/A | N/A | N/A |
| | • PA system Panel. | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | | | N/A |
| <p>The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Shortcomings earlier communicated vide even letter dated 04/01/2018 (C-127) found complied.</p> <p>Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/School/2014/SZ/1235 dated 22/09/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;">  Signature of the Inspecting Officer Name: R.N. Singh Designation: ADO (BCP) </p> | | | | |

New Hostel Block, Delhi Public School, Sector-XII, R.K. Puram, New Delhi-110022

DO (SD)


9/3/18