

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/Auditorium/2018/NDZ/ 457

Dated: 18/3/18

FIRE SAFETY CERTIFICATE

Certified that the Auditorium at Swaminarayan Akshardham Temple, N.H.24, Opp.Nizammuddin Bridge, New Delhi 92, owned/occupied by BAPS Swaminarayan Sanstha, comprised of ground floor only was granted FSC vide letter no. No.F.6/DFS/MS/Auditorium/2015/NDZ/277 dated 27/02/15. The auditorium building was inspected by the officers concerned of this department on 06/03/18 in the presence of Sh.Jayesh Gadhia and found that the auditorium building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D " Assembly Building" with effect from ...18/3/18..... for a period of three years, subject to conditions printed overleaf.

Issued on18/3/18..... at New Delhi by

W
14/3
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

Sh.Jayesh Gadhia
BAPS Swaminarayan Sanstha
Swaminarayan Akshardham Temple, N.H.24,
Opp.Nizammuddin Bridge, New Delhi 92

Copy to:-

The Addl. Commissioner of Police (Lic.),
First Floor, Police Station,
Defence Colony, New Delhi.

9/CRS

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Auditorium at Swaminarayan Akshardham Temple, N.H.24, Opp.Nizammuddin Bridge, New Delhi 92.
2. Building is comprised of : Ground Floor only
3. Type of Occupancy : Assembly
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/Aud./2015/NDZ/277dated 27/02/15
6. Fire Safety direction letter No : NBC Part -IV
7. Date of Inspection : 06/03/18
8. Name of the Inspecting Officers : DO F.Brown & ADO R.K. Yadav
9. Name of the designation of Officer from the building side : Sh.Jayesh Gadhia (Manager)
10. Year of Construction : 2005
11. Applicant's letter No : 124-127/Addl.C.P./Lic.(Amst) dated 11/01/18

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	20 m	MR
	Gate width	4.5 m	06 m	MR
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2no.	2 no.	MR
	Basement	N.A	N.A	N.A
	B. Width of Staircases			
	Upper Floor	2 m	2 m	MR
	Basement	N.A	N.A	N.A
	c. Protection of exits	N.A	N.A	N.A
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	N.A	N.A	N.A
	e. Width of Corridor	N.A	N.A	N.A
	f. Door Size	2 m	2 m	MR
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	Required	sealed	MR
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	Required	Provided	MR
5.	Fire Extinguisher			
	Total numbers	10 nos.	10 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	2 no.	2 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Smoke	Provided	MR
	Location of main panel	Control Room	Provided	MR
	Location of repeater panel	Security Room	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters	Hall	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	01 no.	01 no.	MR
	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	2 no.	2 no.	MR
	Hose Box	2 no.	2 no.	MR
13	Pumping Arrangements.			
	Ground Level			
	Discharge of main Pump	2850 LPM	2850 LPM	MR
	Head of Main Pump	70 M	70 M	MR
	Number of main pumps	1 No.	1 No.	MR
	Jockey pump out put	225 LPM	225 LPM	MR
	Jockey pump head	70 M	70 M	MR
	Standby pump out put	2850 LPM	2850 LPM	MR
	Standby pump Head	70 M	70 M	MR
	Auto Starting /Manual stopping	Required	Provided	MR
	Pump House Access	Required	Provided	MR
	Terrace Level	N.A	N.A	N.A
	Discharge of pump	N.A	N.A	N.A
	Head of the Pump	N.A	N.A	N.A
	Power supply	N.A	N.A	N.A
	Auto starting of pump	N.A	N.A	N.A
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	2,00,000 Ltrs	4,00,000 Ltrs	MR
	Draw-off connection	N.A	Provided	MR
	Fire service inlet	N.A	Provided	MR
	Access to tank	N.A	Provided	MR
	Overhead Tank capacity	N.A	N.A	N.A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	N.A	Provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The Fire Safety Certificate issued vide letter no F.6/DFS/MS/Auditorium/2015/NDZ/277 dated 27/02/15 renewal under the rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Signature of the Inspecting Officer

Name : R. K. Yadav

Designation: ADO(LN)

DO(ED)

395/CF/NA
12/3-19/3

[Handwritten signature]
11/3/18

DUL/NDZ

[Handwritten signature]

CF

M.Scell

FT/NA

12/3

Sir, FT letter is put up for signature pls

M.Scell

[Handwritten signature]
11/3/18