

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001




NO. F6/DFS/MS/School/2018/SZ/512

Dated: 27/03/2018

FIRE SAFETY CERTIFICATE

Certified that the Basava International School, located at Plot No.1, Sector-23, Dwarka, New Delhi-110075, comprised of ground plus three upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2014/SZ/1041 dated 20.8.2014. The said school building was re-inspected by the officer concerned of this department on 12.3.2018 in the presence of Ms. Poornims Ambli (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and that the premises / building is fit for occupancy Class B "Educational Building" with effect from 27/03/2018 for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on 27/03/2018 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service



Copy to:-

- 1 Dy. Director, (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
- 2 Principal, Basava International School, located at Plot No.1, Sector-23, Dwarka, New Delhi-110075.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Basava International School at Plot No.1, Sector 23, Dwarka, New Delhi-110075.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F6/DFS/MS/School/2014/1041 dated 20.8.2014	
5	Fire safety directives letter No	DFS Act 2007/Reles 2010/NBC-IV	
6	Date of inspection	12.3.2018	
7	Name of the inspecting Officers	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Mrs.poornima Ambli (Principal)	
9	Year of construction	2004	
10	Applicant's letter No.	Nil dated 18.7.2014	(ground plus three upper floors)

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ letter dated 9.9.2005	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	5.8 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.66,1.77,1.78 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	3 Nos.	3 Nos.	MR
	e. Width of corridor	1.50 Mtrs.	1.50 to 2.35	MR
	f. Door size	1 Mtr.	1.05 to 1.10 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 ac charge	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	35 Nos.	35 Nos.	MR
	Types	CO2 & ABC	Co2 & ABC	MR
	ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	2 Nos.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100MM	Provided	MR
	Number of Hydrants per floor	2 Nos.	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 180 LPM	Provided	MR
	b. head of the pump	40 M	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	50000 Ltrs.	Provided	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	20000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


1/10

17	Standby power supply	Required	DG Set	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Required	CO2 Fire extinguisher Provided near electri panel	MR

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules , renewal of FSC issued vided letter no.F6/DFS/MS/School/2014/SZ/1041 dated 20.8.2014 is recommended.

Accordingly DFA is put up for your approval and signature please.


 S.P. Bhardwaj
 ADO Dwarka

20/3/18

16/3/18

DCFO (S2)

1123/Ch S2
23/3-27/3.

20/3



cfo s2/ m.scell FT/OT. 25/3.

FT is put up for signature plan

27/3 m.scell 27/3.

26/3/18