

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2018/SZ/ 538

Dated: 28/3/18

**FIRE SAFETY CERTIFICATE**

Certified that **Arya Shishu Shala** located at Arya Samaj Kailash, Greater Kailash-1, New Delhi- 110048, comprised of **Ground plus two upper floors** was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/1636 dated 23/12/2014. The premises was re-inspected by officer concern of this department on 09/03/2018 in presence of Ms. Archana (Principal) and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational**" Group-B as above with effect from the date of issue of this certificate for a period of **Three years** subject to conditions mentioned below.

Issued on 28/3/18..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The Manager, Arya Shishu Shala, Arya Samaj Kailash, Greater Kailash-1, New Delhi-48
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.


**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	ARYA SHISHU SHALA, ARYA SAMAJ KAILASH, GREATER KAILASH-1, NEW DELHI-110048		
2	Type of Occupancy	Educational Building, Group-B		
3	Building Comprised of	Ground plus two upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/1636 Dated 23-12-2014		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 dated 17.01.2005		
7	Date of Inspection	09-03-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Archana (Principal)		
10	Year of construction	1979		
11	Applicant letter No.	Nil Dated 07-02-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	9 mtr	MR
	• Gate width	Required	5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Required	02 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5m / 0.75m	1.04m & 1.19m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e) Width of corridor</b>	-NA-	1.87m	-NA-
	<b>f) Door size</b>	1 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	12 No's	MR
	• Types	ABC / CO2	ABC type	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	One	MR
	• Length of hose-reel hose.	30 mtr	30 mtr	MR
	• Nozzle Diameter	5 mm	5 mm	MR

Arya Shishu Shala, Arya Samaj Kailash-Greater-Kailash-I, New Delhi-110048



19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-
<p>The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under DOE circular, the FSC issued vide letter No. F.6/DFS/MS/School/2014/SZ/1636 Dated 23-12-2014, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">               Signature of the Inspecting Officer              Name: R.N. Singh              Designation: ADO (BCP)         </p>				

Arya Shishu Shala, Arya Samaj Kailash-Greater-Kailash-I, New Delhi-110048

~~DO (SD)~~

*Anilash*  
14/3/18

*By CFO/SP*

1121/cfsc  
23/3/28/3.

*Manoj*  
10/3

*CFO/SP*

*M.Scell* *W*  
22/3

*RT letter is put up for sign-off*

*CFD/SP*

*M.Scell* *W*  
27/3

*Pray*  
26/3

