

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/ 2018/School/ 530

Dated: 27/03/2018

FIRE SAFETY CERTIFICATE

Certified that **C.R.P.F. Public School, Sec-XIV, Rohini, Delhi-110085** Comprised of **Basement, Ground + Three Upper Floors** owned/occupied by **C.R.P.F. Public School** was issued fire safety certificate vide letter no. **F.6/DFS/MS/2015/School/WZ/307** dated **05/03/2015**. The premises was re-inspected by the officer from this department on dated **13/03/2018** in the presence of **Mrs. Nidhi Chaudhary (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition and there is no additional construction. The premises have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and building/premises is fit for occupancy under **Educational class** with effect from **27/03/2018** for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 27/03/18 at New Delhi by

(Atul Garg)

Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, C.R.P.F. Public School, Sec-XIV, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building : C.R.P.F. Public School, Sec-XIV, Rohini, Delhi-110085
2. Type of Occupancy : Educational (B + G + 3)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2015/School/WZ/307 dated 05/03/2015
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 13/03/2018
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers
from the building side : Mrs. Nidhi Choudhary (Principal)
9. Year of Construction : 1992
10. Applicant's letter No. : 2/CRPF(PD)/90-III dated 21/02/2018

	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr	M/R
	• Gate width	4.5 mtr	4.5 mtr	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	M/R
	• Basements	02	02	M/R
	b. Width of staircases			
	• Upper Floors	1.5 m	1.5 m each	M/R Old case
	• Basements	1.5 m	1.5 m each	M/R Old case
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1 mtr	1 mtr	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust fan provided	M/R
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	01 @ 300m each	33	M/R
	<ul style="list-style-type: none"> • Types 		ABC/CO2	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	03	Provided	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	M/R
9	Public Address System.	Required	Provided	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	4"	Provided	M/R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	03	Provided	M/R
	<ul style="list-style-type: none"> • Hose Box 	03	Provided	M/R

12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM 180 LPM	Provided	M/R
		40 m	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	1,00,000 ltr	Provided	M/R
	<ul style="list-style-type: none"> ➤ Draw-off connection 	Required	Provided	M/R
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	M/R
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Overhead Tank capacity 	15,000 ltr	15,000 ltr	M/R
15	Exit Signage.			
		Required	Provided	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A

17	Standby power supply	Required	110 KVA	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2015/School/WZ/307 dated 05/03/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

RK
12/13

Signature of the Inspecting Officer

Name : Rajesh Kumar

Designation: Asstt. Divisional Officer

Du CFO/WZ
CFO WZ
19/3/18
17/3

ADD/RN

FT letter is put up for sign/please

CFO (WZ)
26/3/18

ADD (SPW)
26/3/18

mm