

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/Institute/2018/SZ/ 566

Dated: 31/4/18

FIRE SAFETY CERTIFICATE

Certified that Lingaya'a Lalita Devi Institute of Management & Sciences at Mandi Road, Mandi, New Delhi-110047, comprised of (Main building block) basement, ground plus three upper floors Owned/Occupied by Lingaya'a Lalita Devi Institute of Management & Sciences was issued FSC by this department vide letter No. F6/DFS/MS/Institute/2014/SZ/1677 dated 30-12-2014. The premise was re-inspected by officer concern of this department on 14/03/2018 in presence of Sh. Vijay Pal (Admin) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational Building' Group-B **for main block only** as above with effect from 31/4/2018 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/4/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. Dr. K.K. Garg (Director), Lingaya'a Lalita Devi Institute of Management & Sciences at 847-848, Mandi Road, Mandi, Near Chattarpur Metro Station, New Delhi-110047
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept unlocked & free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	Lingaya's Lalita Devi Institute of Management & Sciences (Main Building), Mandi Road, Mandi, New Delhi-110047		
2	Type of Occupancy	Educational Building "Group-B"(Institute)		
3	Building Comprised of	Institute is running in two blocks i.e. Block- A & B, each comprised of Basement, Ground plus three upper floors		
4	Type of Case	Renewal of FSC for Main building (Block-A) only.		
5	Details of Previous NOC	F.6/DFS/MS/Institute/2014/SZ/1677 Dated 30-12-2014		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14-03-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Vijay Pal (Admin)		
10	Year of construction	2004		
11	Applicant letter No.	2254/LLDIMS/Dir./2018 Dated 03-01-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	• Upper floors	Required	2 Nos	MR
	• Basement floor	Required	1 + 1 ramp	MR
	b) Width of Staircase			
	• Upper floors	1.5 mtr	1.7m & 1.2m	MR
	• Basement floor	1.5 mtr	1.7m & 2m ramp	MR
	c) Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	17 Nos	MR
	• Types	ABC / CO2	Co2, ABC, W.CO2	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 mts	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR


7	Automatic fire detection & alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	NA	NA
8.	MOEFA	-NA-	Provided	-NA-
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	01 No	MR
	• Hose box.	Required	01 No	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	900 LPM	900 & 180 LPM	MR
	➤ Head of pump.	35 mts.	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	75,000 Ltr.	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	15,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The Fire protection systems provided in the (Block A) main building were test checked at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/Institute/2014/SZ/1677 dated 30.12.2014, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.



Signature of the Inspecting Officer
 Name: R.N. Singh
 Designation: ADO (BCP)

Lingaya's Lalita Devi Institute of Management & Sciences, Mandi Road, Mandi, New Delhi-110047

DO (SD)

Amilash
 22/3/18
 Dy. CPO (SD)

deef
 22/3 FT 10.

efo/sr m.sell 26/3

FT letter is put up for sign. file.
Amilash
 31/3

efo/sr m.sell 31/3



1136/CPO SR
 28/3/2014.