

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2018/SZ/ 574

Dated: 3/4/18.

FIRE SAFETY CERTIFICATE

Certified that **South Delhi Model School** located at Block K-1/18/174, Sangam Vihar, New Delhi-110080, comprised of **Ground plus two upper floors** was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2015/SZ/238 dated 19/02/2015. The premises was re-inspected by officer concern of this department on 10/03/2018 in presence of Sh. Satpal Chauhan (Manager) and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational**" Group-B as above with effect from 3/4/2018 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on ...3/4/18.. at New Delhi by

W
3/4.
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Manager, South Delhi Model School, K-1/18/174, Sangam Vihar, New Delhi-110080
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

| INSPECTION REPORT | | | | |
|-------------------|---|--|----------------------|----------------|
| 1 | Name & Address of the Building | SOUTH DELHI MODEL SCHOOL, K-1/18/174, SANGAM VIHAR, NEW DELHI-110080 | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | Ground plus two upper floors. | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F.6/DFS/MS/School/2015/SZ/238 Dated 19-02-2015 | | |
| 6 | Fire Safety Directives Letter No | F.16//Estate/CC/Fire Safety/2011/3298-3398 Dt. 01.03.2011 | | |
| 7 | Date of Inspection | 10-03-2018 | | |
| 8 | Name of the Inspecting Officers | R.N. Singh, ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Smt. Anita Pandey (Principal) | | |
| 10 | Year of construction | 2000 | | |
| 11 | Applicant letter No. | 69/SDMS/2018 Dated 17-02-2018 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC requirements | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | Required | 6 mtr | MR |
| | • Gate width | -NA- | 4 mtr | -NA- |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | Required | 02 Nos | MR |
| | ➤ Basement floor. | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.5m / 0.75m | 1.18 to 1.35m & 1.0m | MR |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | Required | One | MR |
| | e) Width of corridor | -NA- | -NA- | -NA- |
| | f) Door size | 1m | Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | 30 ACPH | -NA- | -NA- |
| | • Upper floors | 12 ACPH | -NA- | -NA- |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | 08 No's | 08 No's | MR |
| | • Types | ABC / CO2 | ABC type | MR |
| | • ISI Marking | Required | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | One | Provided | MR |
| | • Length of hose-reel hose. | 30m | Provided | MR |
| | • Nozzle Diameter | 5 mm | Provided | MR |


South Delhi Model School, K-1/18/174, Sangam Vihar, New Delhi-110080

| | | | | | |
|-----|---|--------------------------|---|------|------|
| 19. | Fire Control Room. | • Detector system panel. | -NA- | -NA- | -NA- |
| | | • Flow switch panel. | -NA- | -NA- | -NA- |
| | | • PA system panel. | -NA- | -NA- | -NA- |
| | | • Battery backup. | -NA- | -NA- | -NA- |
| | | • Building floor plan. | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | Required | Provided one ABC type fire extinguisher near elect. panel | MR | |

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under DOE circular, the FSC issued vide letter No. F.6/DFS/MS/School/2015/SZ/238 Dated 19-02-2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


Accordingly DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name : R.N. Singh
 Designation: ADO (BCP)

South Delhi Model School, K-1/18/174, Sangam Vihar, New Delhi-110080

DO (SD)


15/3/18

By 



19/3

FT/101.

CFAS/1

M-SCEU


27/3

F.T letter is put up for signature 
31/3

CFD/SP

M-SCEU


3/4



1143/CF/82
24/3/18