

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/2018/ 1402/577

Dated : 4/4/18

FIRE SAFETY CERTIFICATE

Certified that the **Constitution Club of India** located at **Rafi Marg, New Delhi** comprised of **Ground + 02 Upper floors, presently running at ground & first floor** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 09/01/2018 in the presence of Sh. Nacerudin Khan AE (E) & Sh. Sunil Kumar JE (E) that the premises is fit for occupancy class **Assembly Building Group D at Ground & first floor only** with effect from 4/4/18 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued 4/4/18 at New Delhi by.

(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Manager (Admin),
Constitution Club of India at Vithal Bhai Patel House, Rafi Marg, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/22

INSPECTION REPORT

1. Name & address of the building : **Constitution Club of India, New Delhi**
2. Type of occupancy : **Assembly Building Gr. + 02 upper floor**
Presently is running at ground & first floor
3. Type of case:- : **New Case**
4. Details of previous NOC : **N/A**
5. Fire safety directives No. : **N/A**
6. Date of inspection:- : **09/01/18**
7. Name of the inspecting officer : **Sh. Gurmukh Singh DO/CD & Sh. M.K. Sharma ADO/CC**
8. Name & designation of officer : **Sh. Narcerudin Khan AE (E) & Sh. Sunil Kumar JE (E)**
From the building side
9. Year of construction : **2006**
10. Applicant's letter No : **AE/ED-4/VD-2/2017-18/54 dated 27/01/2018**
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	36.5 Mtr.	MR
	2) Gate width	06 mtr.	06 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.40 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	01 Nos.	01 Nos.	MR
	E. Width of corridor	NA	NA	NA
	F. Door size	01 mtr.	01mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	1) Basements	NA	NA	NA
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	14	14	MR
	2) Types	ABC, CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR

MR

6.	First-Aid Hose Reel			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	NA	NA	NA
	5) Hooter's Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	NA	NA	NA
	2) Upper floors	NA	NA	NA
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per Basement	02	02	MR
	3) Hose box each floor	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	NA	NA	NA
	2) Hose box	NA	NA	NA
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	90 mtr.	90 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	90 mtr.	90 mtr.	MR
	f) Stand by pump output	2280 LPM	2280 LPM	NA
	g) Stand by pump head	90 mtr.	90 mtr.	NA
	h) Auto starting/Manual stopping	Required	NA	NA
	2) Terrace level			
	a) Discharge of pump	450 LPM	PNF	MR
	b) Head of pump	30 mtr.	PNF	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltr.	50,000 ltr.	MR
	a) Draw-off connection	NA	NA	NA
	b) Fire service inlet	NA	NA	NA
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 liter.	20,000 liter.	MR
15.	Exit Signage.	Required	Provided	MR

1/24

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	NA	NA	NA
	Total area location	NA	NA	NA
19.	Fire Control Room			
	a) Detector system panel	NA	NA	NA
	b) Flow switch panel	NA	NA	NA
	c) PA system panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building floor plan	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2017/2161 dated 21/08/2017 have been rectified. ✓

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

G.S Chauhan

Name :- G.S Chauhan
Designation :- DO (CD)

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma
Designation :- ADO (CC)

Dy CRO (NO2)

[Signature]
28/2

- L.F.C.

M.S.C.U.

F.T.M.

1/3.

F.T. letter is put up for signature

AD (NO2)

received on 28/3/18

[Signature]

10/CF/NO2
21/08/17