

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2015/NDZ/593

Dated: 10/4/18

**FIRE SAFETY CERTIFICATE**

Certified that the Pragati Public School, A-312/4, Gali no.4, South Gamri, Delhi-53, comprised of ground plus one upper floors owned/occupied by Pragati Public School was issued FSC vide letter No. F6/DFS/MS/School/2015/NDZ/593 Dated 23/04/15. The school building was inspected by the officer concerned of this department on 21/03/18 in the presence of Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' with effect from 10/4/18 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 10/4/2018 at New Delhi by

(Vipin Kental)  
Chief Fire Officer

To,

The Principal,  
Pragati Public School, A-312/4, Gali no.4, South Gamri, Delhi-53

Copy to:-

The Director of Education,  
Udyog Sadan, Plot No.419, FIE,  
Patparganj Industrial Area, Delhi-110092.

**- Conditions -**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

AOC/LN

1. Name & address of the building : Pragati Public School, A-312/4, Galino.4, South  
Gamri, Delhi-53.
2. Building is comprised of : Ground plus one upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2015/NDZ/593 Dated 23/04/15
6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 to 3398  
dt. 01/03/11
7. Date of Inspection : 21/03/18
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer:  
from the building side : Manager
10. Year of Construction : 2003
11. Applicant's letter no. : Nil dated 01/03/18

S. N	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	06 m	4.5 m	MR old accepted
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	1 no.	2 no.	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A.	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	1.5 m	.95 & .90m	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1no.	1 no.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1.0 Mtr.	1.0 mtr.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Water curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floor</li> </ul>	N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	04 nos.	04 nos.	MR
	<ul style="list-style-type: none"> <li>types</li> </ul>	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2015/NDZ/593 Dated 23/04/15 renewal under the circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 is recommended.

*R. K. Yadav*  
22/3/2018

Signature of the Inspecting officer  
Name- R.K. Yadav  
Designation- ADO

DO (East)

*[Signature]*  
23/3

416/CF/NDZ  
27/2/2018

DYCF/NDZ  
*[Signature]*

*[Signature]*

E.F. M. scull 26/3

See FT letter is put up for signature ps

*[Signature]*  
6/4/2018

CF/NDZ M. scull