

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/NDZ/2018/849

Dated: 10.04.18

FIRE SAFETY CERTIFICATE

Certified that the M/S River Side Club Mayur Vihar phase-1 Delhi, comprised of Basement, ground plus two upper floors owned / occupied by Riverside Sports & Recreation Club, have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 14/03/2018 in the presence of Sh. Manoj (Manager) and found that the Assembly building is fit for occupancy class "D" with effect from 10.04.18 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10.04.18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to:-

1. The Asstt. Commissioner (Club)
GNCT OF Delhi, L&N Block,
Vikas Bhawan, IP Estate,
Delhi 110002

Exp. No.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
1. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
2. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
3. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
5. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : River Side Club Mayur Vihar phase-1 Delhi
2. Building is comprised of : B+ G+ Two upper floors
3. Type of Occupancy : Assembly (Club Building)
4. Type of Case : Renewal
5. Details of Previous FSC : DFS/MS/Club/2015/NDZ/454/dated-27/03/2015
- 6.. Fire Safety direction letter No : F.6/DFS/MS/BP/97/481/dated-1/05/1997
7. Date of Inspection : 14/03/18,
8. Name of the Inspecting Officers: : DO. F. Brown
9. Name of the designation of Officer
from the building side : SH. Manoj (Manager)
10. Year of Construction : 1999
11. Applicant's letter No :RSRC/FF/2018, 28/2/2018

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement Directive	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 m	30 m	MR
	Gate width	4.5m	6m	MR
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02 Nos.	02 Nos.	MR
	Basement	02 Nos.	02 + 1ramp	MR
	B. Width of Staircases			
	Upper Floor	1.25 M	1.4 M&80cm	MR
	Basement	1.25 M	1.4	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 M.	1.5M.	MR
	h. Door Size	1.0 Mtrs.	1.0 M	MR
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Sealed	MR
	Fire rating of shaft door	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	Basement	Required	Provided	MR
	Upper floor	NA	NA	NA
5.	Fire Extinguisher			
	Total numbers	15 Nos.	20 Nos.	MR
	types	ABC type & Co2	ABC type & Co2	MR
	IS marking	ISI marked	ISI marked	MR

ONE STAIRCASE OF 80 cm IS UP TO FIRST FLOOR ONLY

6	First-aid-Hose Reels.			
	Total numbers of 2 nd floors	01 nos.	01 nos.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of main panel	NA	NA	NA
	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	Hooters	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floor	NA	NA	NA
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	01 nos.	01 nos.	MR
	Hose box each floor	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	60 mtrs	60 mtrs	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50,000 Ltrs.	50,000 Ltrs.	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	12,5,00 Ltrs.	12,500 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of Fire prevention and Fire Safety measured as required under the directive issued vide latter no. : DFS/MS/Club/2015/NDZ/454/dated-27/03/2015

The Fire safety certificate issued under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Handwritten Signature]
16/3/18

Signature of the Inspecting Officer

Name : F.BROWN

Designation : DO

443/CFD NDZ
4/14

Dy. CFO (NDZ) *[Signature]*
23/3

F7D.

m.sceM
4/2/14

C.F.P.