

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 612

Dated: 6/4/18

**FIRE SAFETY CERTIFICATE**

Certified that **Apeejay School** located at J-Block, Gurudwara Road, Saket, New Delhi-110017 comprised of Basement, Ground and three upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/MS/DFS/School/2014/SZ/1103 Dated 01/09/2014. The school premises was re-inspected by officer concerned of this department on 23/03/2018 in presence of Mr. Anand Kr. Pandey (Admin) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions mentioned below.

Issued on 6/4/18 at New Delhi by

*WST/4*  
(Vipin Kental)  
Chief Fire Officer  
*R*  
*o/c*

Copy to: -

1. The Principal, Apeejay School, J-Block, Gurudwara Road, Saket, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	APEEJAY SCHOOL, J-BLOCK, GURUDWARA ROAD, SAKET, NEW DELHI-110017		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground plus three upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/School/2014/SZ/1103 Dt. 01/09/2014		
6	Fire Safety Directives Letter No	DOE circular No 262-362 dated 17/01/2005		
7	Date of Inspection	23-03-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Anand Kr. Pandey (Admin)		
10	Year of construction	1988		
11	Applicant letter No.	APJ/S/2017-18/475 dated 26-02-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	9 mtr	MR
	• Gate width	Required	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	Required	3 No's	MR
	➤ Basement floor	Required	3 No's	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required	1.45m, 1.44m & 1.42m	MR
	➤ Basement floor	Required	1.42m, 1.42m & 1.23m	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	Three	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	1 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	13 No's	13 No's	MR
	• Types	ABC / Co2	ABC-08 & Co2-05	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

Apeejay School, J-Block, Gurdwara Road, Saket, New Delhi-110017


7	<b>Automatic fire detection &amp; alarming system</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	Provided	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	N/A	Three	N/A
	• Hose box.	N/A	Three	N/A
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	900 LPM	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 ltrs	5,000 ltrs	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provisions of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	<b>Fire Control Room.</b>	• Detector System Panel.	N/A	N/A	N/A
		• Flow Switch Panel.	N/A	N/A	N/A
		• PA system Panel.	N/A	N/A	N/A
		• Battery backup	N/A	N/A	N/A
		• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	One Co2 type fire extinguisher provided near electrical panel	N/A	

The Fire protection systems provided in the building were checked / operated at random and found functional at the time of inspection. The shortcomings communicated vide letter dated 30/11/2017 (C-20) has been complied by school management


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under Directorate of Education circular, Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2014/SZ/1103 dated 01/09/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: R.N. Singh  
 Designation: ADO (BCP)

Apeejay School, J-Block, Gurdwara Road, Saket, New Delhi-110017

DO (SD)

  
22/3/18

115-y/CF/SZ  
2/4. 16/4.  
22/3/18  
2429



depl  
22/3

CF/SZ

m.scell

FT/17.

u  
2/4.

FT letter is put up for sign. pda.

CF/SZ

m.scell

u  
2/4.

22/3/18  
0314