

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2018/ 619

Dated: 6/4/18

FIRE SAFETY CERTIFICATE

Certified that **Govt. Boys/Girls Sr. Sec. School located at New Rohtak Road, New Delhi- 110005** is comprised of ground plus three upper floors was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2015/SZ/949 dated 09/06/2015. The school building was re-inspected by the officer concerned of this department on 21/03/2018 in presence of Mrs. Sangeeta Thareja, head of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the under mentioned conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 6/4/18 at New Delhi by.


(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to: -

1. The H.O.S, Govt. Girls Sr. Sec. School, New Rohtak Road, Karol Bagh, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Boys/Girls Sr. Sec. School, New Rohtak Road, Karol Bagh, New Delhi- 110005
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2015/SZ/949 dated 09/06/2015
5. Fire Safety directives letter No : Delhi Fire Service Act- 2007 & Rules- 2010
6. Date of inspection : 21.03.2018
7. Name of the Inspecting Officers : M.K. Chattopadhyay, Divisional Officer (South West)
8. Name and designation of officers from the building side : Smt. Sangeeta Thareja, H.O.S
9. Year of Construction : Before 2000
10. Applicant's letter No. : Form 'J' dated nil

Govt. Boys/Girls Sr. Sec. School, New Rohtak Road, Karol Bagh, New Delhi- 110005 is comprised of ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per letter dt. 09.06.2015	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt	1.85 mts.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts	2.40 mts	MR
	h. Door Size	1.0 mts	0.95 mt.	MR, old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	----
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			


	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM	02 x 450 LPM	MR
	➤ Head of the pump	30 mts.	30 mts. each	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	----
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 lts.	10,000 lts.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection

2/14


In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2015/SZ/949 dated 09/06/2015, renewal under rule 35 of Delhi Fire Service Rules- 2010, is recommended.

DFA is put up for approval & signature please


22/3/18

Signature of the Inspecting Officer
(M.K. CHATTOPADHYAY)
Divisional Officer, (South West)

DCFO (SZ)


22/3/18


77/00/SW
22/03/2018

Cfo c sz

m.scell FT 01
22/3/18



F-T. letter is put up for Sign. please


24/3/18

1186/cfoSZ
6/4.

cfo (sz) m.scell
26/4.